



CROSS REFERENCE GUIDE

2013 Building Code Update for Accessibility

This document provides a cross reference between the accessibility provisions of the 2010 California Building Code and the 2013 California Building Code as adopted by the California Building Standards Commission on January 24, 2013.

This guide is organized as follows:

- Provisions in the 2010 California Building Code (column one).
- Corresponding provisions in the 2013 California Building Code (column two).
- Commentary (column three).

Portions of the 2010 California Building Code, Chapter 11A not referenced in this document are either duplicative, not as stringent or in conflict with 2013 Chapter 11B and are no longer adopted by the Division of the State Architect – Access Compliance.

2013 California Building Code Update for Accessibility

Cross Reference Guide – Accessibility provisions in the 2010 CBC to the 2013 CBC

Table of Contents

Chapter 11B - Accessibility to Public Buildings, Public Accommodations, Commercial Buildings and Publicly Funded Housing

| | |
|---|----|
| Section 1101B Scope | 3 |
| Section 1102B Definitions..... | 4 |
| Section 1103B Building Accessibility | 5 |
| Section 1104B Accessibility for Group A Occupancies | 6 |
| Section 1105B Accessibility for Group B Occupancies | 15 |
| Section 1106B Accessibility for Group E Occupancies | 20 |
| Section 1107B Factories and Warehouses | 22 |
| Section 1108B Accessibility for Group H Occupancies | 24 |
| Section 1109B Accessibility for Group I Occupancies..... | 25 |
| Section 1110B Accessibility for Group M Occupancies..... | 27 |
| Section 1111B Accessibility for Group R Occupancies | 29 |
| Section 1112B Reserved | 34 |
| Section 1113B Reserved | 34 |
| Section 1114B Facility Accessibility | 35 |
| Section 1115B Bathing and Toilet Facilities (Sanitary Facilities) | 37 |
| Section 1116B Elevators and Platform (Wheelchair) Lifts | 44 |
| Section 1117B Other Building Components..... | 48 |
| Section 1118B Space Allowance and Reach Ranges..... | 56 |
| Section 1119B Special Standards of Accessibility for Buildings with Historical Significance | 57 |
| Section 1120B Floor and Levels | 58 |
| Section 1121B Transportation Facilities..... | 59 |
| Section 1122B Fixed or Built-In Seating, Tables and Counters..... | 63 |
| Section 1123B Access to Employee Areas | 64 |
| Section 1124B Ground and Floor Surfaces..... | 65 |
| Section 1125B Storage..... | 66 |
| Section 1126B Vending Machines and Other Equipment..... | 67 |
| Section 1127B Exterior Routes of Travel | 68 |

| | |
|--|-----------|
| Section 1128B Pedestrian Grade Separations (Overpasses and Underpasses) | 70 |
| Section 1129B Accessible Parking Required | 71 |
| Section 1130B Parking Structures | 74 |
| Section 1131B Passenger Drop-Off and Loading Zones..... | 75 |
| Section 1132B Outdoor Occupancies | 76 |
| Section 1133B General Accessibility for Entrances, Exits and Paths of Travel | 78 |
| Section 1134B – Accessibility for Existing Buildings | 89 |
| Section 1135B Historic Preservation-Special Standards for Accessibility for Buildings with Historical Significance | 94 |
| Chapter 11C – Standards for Card Readers at Gasoline Fuel-Dispensing Facilities | 95 |
| Chapter 11A – Housing Accessibility | |
| Section 1101A Application | 97 |
| Section 1102A Building Accessibility | 98 |
| Section 1104A Covered Multifamily Dwellings | 100 |
| Section 1106A Site and Building Characteristics | 101 |
| Section 1109A Parking Facilities | 102 |
| Section 1114A Exterior Ramps and Landings on Accessible Routes..... | 103 |
| Division IV Dwelling Unit Features | 104 |
| Division VI Site Impracticality Tests | 106 |

Section 1101B Scope

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|---|
| Section 1101B SCOPE | 11B-107 | Preserves reference to Chapter 1, Section 1.9.1.5 making the findings and determinations rendered by a local enforcement agency subject to ratification through an appeals process. |
| 1101B.1 General | N/A | Title only in 2010 CBC |
| 1. | 11B-101.1 General | General scoping for buildings and facilities |
| 2. | 11B-103 Equivalent Facilitation | General scoping for equivalent facilitation |
| 3. | 11B-103 Equivalent Facilitation | General scoping for equivalent facilitation |
| 1101B.2 Design | 11B-101.1 General | General scoping for buildings and facilities |
| 1101B.3 Maintenance of accessible features | 11B-108 Maintenance of Accessible Features | 2010 ADAS addresses maintenance only in advisory language; this section maintains current CBC requirement. |
| 1101B.4 Dimension Conventions. | 11B-104.1 Dimensions | Figure 11B-104 from ADA provides graphic conventions for figures. |
| 1101B.5 Constructing and manufacturing tolerances. | 11B-104.1.1 Construction and Manufacturing Tolerances | All dimensions are subject to conventional industry tolerances except where the requirement is stated as a range with specific minimum and maximum end points. |
| 1101B.6 Commercial facilities located in private residences. | 11B-245 Commercial Facilities Located in Private Residences | 2010 ADA and 2010 CBC are equivalent. This is a scoping provision and has been included in Chapter 11B Division 2. |
| 1101B.7 Provisions for Adults | 11B-102 Dimensions for Adults and Children | ADA and CBC equivalent. |

Section 1102B Definitions

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|----------------------|--|---|
| 1102B DEFINITIONS | 11B-106 Definitions | Because California amendments to the ADA Model Code language will be in italics, defined terms within the code language will not be shown italicized. |
| | <ul style="list-style-type: none">• 11B-106.5 Defined Terms• Chapter 2, Section 202 | To conform to the format of the 2013 CBC, definitions will be located in Chapter 2, with a list of defined terms appearing in 11B-106. |

Section 1103B Building Accessibility

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|-------------------------------|---|---|
| 1103B.1 SCOPE | 11B-101.1 General | This section establishes that the requirements for accessibility are found in Chapter 11B and applies them to sites, facilities, buildings and elements to the extent set forth in the regulations. |
| Second paragraph | <ul style="list-style-type: none"> • 11B-403.1 General • 11B-403.5 Clearances • 11B-403.5.1 Clear Width • 11B-403.5.2 Clear Width at Turns • 11B-206.6 Elevators | |
| Exception 1 | <ul style="list-style-type: none"> • 11B-203.4 Limited Access Spaces • 11B-203.5 Machinery Spaces • 11B-206.2.8 Exceptions 1, 2 & 3 | |
| Exception 2 | 11B-206.2.3 | Both 2010 CBC and ADA do not require ramp or elevator access to above or below the first floor for certain small facilities as noted in Exceptions 2.1 and 2.2. |
| Exception 2.1 | 11B-206.2.3 Multi-Story Buildings and Facilities, Exception 1 | The specific 2010 CBC Exception language for small office buildings and passenger vehicle service stations has been added to clarify that the second condition in Exception 1 does not apply. |
| Exception 2.2 | 11B-206.2.3 Multi-Story Buildings and Facilities, Exception 1 | The conditional language from the 2010 CBC Exception has been added to the ADA language. |
| Third Paragraph | 11B-213.2 Toilet Rooms and Bathing Rooms | This section requires accessible toilet and bathing facilities be provided on an accessible route |
| Fifth Paragraph | 11B-206.2.3.1 Stairs & Escalators in Existing Buildings | This section requires accessible route when stair or escalator is provided in alteration |
| 1103B.2 Distance to Elevators | 11B-206.2.3.2 Distance to Elevators | This section from 2010 CBC for maximum distance to elevators. |

Section 1104B Accessibility for Group A Occupancies

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|--|---|
| 1104B.1 General | 11B-101.1 General | This section establishes that the requirements for accessibility are found in Chapter 11B and applies them to sites, facilities, buildings and elements to the extent set forth in the regulations. |
| 1104B.2 Assistive listening systems in assembly areas. | 11B-219.2 Required Systems | Scoping for assistive listening systems; amends model code language to remove implied exception when audible communications is not integral to the use of the space. |
| Exception. | 11B-219.2 Required Systems, Exception: Paging, and background music | Scoping for assistive listening systems; amends model code language to narrow scope of exception and maintain current 2010 CBC exception for paging and background music systems. |
| 1. Number of personal receivers required | 11B-219.3 Receivers | Scoping for number of receivers required; amends model code language to maintain current 2010 CBC requirements. |
| 2. Types of listening systems | 11B-706 Assistive Listening Systems | Technical requirements for assistive listening systems. Model code language provides more detailed technical performance specifications. |
| 3. Location | 11B-219.4 Location | Scoping for location of assistive listening systems; amends model code with current 2010 CBC provisions regarding location when not all seats are covered by the assistive listening system. |
| 4. Signage | <ul style="list-style-type: none"> • 11B-216.10 Assistive Listening Systems • 11B-703.5 Visual Characters • 11B-703.7.2.4 Assistive Listening Systems | <p>Scoping for signage required for availability of assistive listening systems.</p> <p>Technical requirements for assistive listening systems signage</p> |
| 5. Fees and Charges | N/A | Operational issue not enforceable by building officials; current 2010 CBC provisions not carried forward. |
| 6. Permanent and Portable Systems | 11B-219.5 Permanent and Portable Systems. | Scoping for permanent and portable assistive listening systems; amends model code with current 2010 CBC provisions regarding permanent and portable assistive listening systems. |
| 1104B.3 Auditoriums, assembly halls, theaters and related facilities. | 11B-221 Assembly Areas | Scoping for assembly areas. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|--|--|
| 1104B.3.1 Seating | 11B-221.1 General | Scoping for wheelchair spaces, companion seats, designated aisle seats and semi-ambulant seats. |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1104B.3.2 Accessibility to key facilities. | 11B-206.2.4 Spaces and Elements | Scoping for accessible route connecting entrances, accessible spaces and accessible elements. |
| 1104B.3.3 Variety of locations. | <ul style="list-style-type: none"> • 11B-221.2 Wheelchair Spaces • 11B-221.2.1.2 Luxury Boxes, Club Boxes, and Suites in Arenas, Stadiums and Grandstands. • 11B-221.2.1.3 Other Boxes • 11B-221.2.1.4 Team or Player Seating • 11B-221.2.3 Lines of Sight and Dispersion | Scoping for accessible seating dispersion. |
| 1104B.3.4 Wheel Chair Spaces 1. Number of such spaces is as shown in table 11B-1. | <ul style="list-style-type: none"> • 11B-221.2 Wheelchair Spaces • Table 11B-221.2.1.1 Number of Wheelchair Spaces in Assembly Areas | Scoping for the minimum number of wheelchair spaces. |
| 1104B.3.4 Wheel Chair Spaces 2. The ground or . . . | 11B-802.1.1 Floor or Ground Surface | Technical requirements for level floor or ground surface at wheelchair spaces. Slopes of 1:48 maximum are permitted. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 1104B.3.5 Placement of wheelchair locations. | <ul style="list-style-type: none"> • 11B-221.2.2 Integration • 11B-221.2.1.2 Luxury Boxes, Club Boxes, and Suites in Arenas, Stadiums and Grandstands. • 11B-221.2.1.3 Other Boxes • 11B-221.2.1.4 Team or Player Seating • 11B-221.2.3 Lines of Sight and Dispersion • 11B-802.1.4 Approach • 11B-207 Accessible Means of Egress • 11B-221.3 Companion Seats | <p>Scoping for the number of wheel chair spaces and their integration into the seating plan, dispersion, sight lines and other locational factors.</p> <p>Technical requirements for adjoining accessible route.</p> <p>Scoping for companion seats at wheel chair spaces.</p> |
| Exception 1 | 11B-221.2.3.1 Horizontal Dispersion, Exceptions | Scoping for dispersion where 300 or less seating capacity. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1104B.3.6 Size of wheelchair location. | <ul style="list-style-type: none"> • 11B-802.1 Wheelchair Spaces • 11B-802.1.4 Approach | <p>Technical requirements for size of wheelchair spaces.</p> <p>Technical requirements for wheel chair spaces to adjoin an accessible route.</p> |
| 1104B.3.7 Readily removable seats. | N/A | Not allowed under the 2010 ADAS, current 2010 CBC provisions not carried forward. |
| 1104B.3.8 Seating for semi-ambulant individuals. | <ul style="list-style-type: none"> • 11B-221.1 General • 11B-221.6 Semi-Ambulant Seats • 11B-802.5 Semi-Ambulant Seats | <p>Scoping for semi-ambulant seats; model code has been amended to include 2010 CBC requirements.</p> <p>Technical requirements for semi-ambulant seats.</p> |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 1104B.3.9 Designated aisle seats. | <ul style="list-style-type: none"> • 11B-802.4 Designated Aisle Seats • 11B-802.4.1 Armrests • 11B-802.4.2 Identification | Technical requirements for designated aisle seats. |
| 1104B.3.10 Life safety. | N/A | Compliance with fire and life safety requirements for all seats is mandated by Chapter 10. Redundant 2010 CBC provision not carried forward. |
| 1104B.3.11 Access to performing areas. | 11B-206.2.6 Performance Areas | Scoping for access to performance areas including ancillary areas. |
| 1104B.3.12 Stages, enclosed and unenclosed platforms and orchestra pits. | 11B-206.7.1 Performance Areas and Speakers Platforms | Scoping to allow platform lifts to access performance areas and speaker's platforms. |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1104B.3.13 Ticket booths. | <ul style="list-style-type: none"> • Chapter 2 – Section 202 • 11B-203.9 Employee Work Areas • 11B-206.2.4 Spaces and Elements • 11B-904.4 Sales and Service Counters | <p>Definition of Workstation</p> <p>Scoping for Employee Work Area</p> <p>Scoping for accessible route connecting entrances, accessible spaces and accessible elements.</p> |
| 1104B.3.14 Miscellaneous areas. | <ul style="list-style-type: none"> • 11B-206.2.4 Spaces and Elements • Division 6: Plumbing Elements and Facilities | Scoping for accessible route connecting entrances, accessible spaces and accessible elements, including toilet facilities. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 1104B.4 Stadiums, grandstands, bleachers, athletic pavilions, gymnasiums, and miscellaneous sports-related facilities. | N/A | Title only in 2010 CBC. |
| 1104B.4.1 Spectator Seating | <ul style="list-style-type: none"> • 11B-221.1 General • 202 DEFINITIONS – Assembly Area | Scoping for accessible seating |
| 1104B.4.2 Ticket Booths | <ul style="list-style-type: none"> • Chapter 2 – Section 202 • 11B-203.9 Employee Work Areas • 11B-206.2.4 Spaces and Elements • 11B-904.4 Sales and Service Counters | <p>Definition of Workstation</p> <p>Scoping for Employee Work Area</p> <p>Scoping for accessible route connecting entrances, accessible spaces and accessible elements.</p> |
| 1104B.4.3 Participation Areas | 11B-206.2.4 Spaces and Elements | Scoping for accessible route connecting entrances, accessible spaces and accessible elements. |
| 1. Tennis, racquetball and handball courts. | <ul style="list-style-type: none"> • 11B-206.2.4 Spaces and Elements • 11B-302.1 General, Exception • 11B-303.1 General, Exception | <p>Scoping for accessible route connecting entrances, accessible spaces and accessible elements up to the edge of the areas of sport activity.</p> <p>Model code technical exceptions from the general requirement for areas of sport activity to be “firm, stable and slip resistant” with changes in level not exceeding ½ inch. While areas of sport activity for certain sports can meet these requirements because of the inherent nature of surface on which they are played, many cannot.</p> |
| 2. Gymnasium floor areas and general exercise rooms. | <ul style="list-style-type: none"> • 11B-206.2.4 Spaces and Elements • 11B-302.1 General, Exception • 11B-303.1 General, Exception | <p>Scoping for accessible route connecting entrances, accessible spaces and accessible elements up to the edge of the areas of sport activity.</p> <p>Model code technical exceptions from the general requirement for areas of sport activity to be “firm, stable and slip resistant” with changes in level not exceeding ½ inch. While areas of sport activity for certain sports can meet these requirements because of the inherent nature of surface on which they are played, many cannot.</p> |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 3. Basketball, volleyball and badminton courts and bowling lanes. | <ul style="list-style-type: none"> • 11B-206.2.4 Spaces and Elements • 11B-302.1 General, Exception • 11B-303.1 General, Exception | <p>Scoping for accessible route connecting entrances, accessible spaces and accessible elements up to the edge of the areas of sport activity.</p> <p>Model code technical exceptions from the general requirement for areas of sport activity to be “firm, stable and slip resistant” with changes in level not exceeding ½ inch. While areas of sport activity for certain sports can meet these requirements because of the inherent nature of surface on which they are played, many cannot.</p> |
| 4. Swimming pool deck areas . . . | <ul style="list-style-type: none"> • 11B-242 Swimming Pools, Wading Pools, and Spas • 11B-1009 Swimming Pools, Wading Pools, and Spas | <p>Scoping for swimming pools, wading pools, and spas.</p> <p>Technical requirements for swimming pools, wading pools, and spas.</p> |
| 4.1 Have a seat . . . | N/A | Title only in 2010 CBC. |
| 4.1.1. Seat shall be rigid . . . | 11B-1009.2.4 Seat | Technical requirements for a rigid seat. |
| 4.1.2. Seat height | 11B-1009.2.4 Seat | Technical requirements for seat height. |
| 4.1.3. Armrests | 11B-1009.2.6 Footrests and Armrests | Model code amended to add technical requirements for two armrests. |
| 4.1.4. Back support | 11B-1009.2.4 Seat | Technical requirements for back support. |
| 4.1.5. Occupant restraint | 11B-1009.2.4 Seat | Model code amended to add technical requirements for seat restraint. |
| 4.2 Be capable of . . . | 11B-1009.2.7 Operation | Technical requirement for unassisted operation. |
| 4.3 Be stable and . . . | 11B-1009.2.7 Operation | Model code amended to add technical requirements for stable operation without unintended movement. |
| 4.4 Be designed to . . . | 11B-1009.2.9 Lift Capacity | Technical requirements for lift capacity, 300 lbs. minimum. |
| 4.5 Be positioned so . . . | 11B-1009.2.1 Pool Lift Location Exception 3 | Technical requirements for water level. |
| 4.6 Lower the operator . . . | 11B-1009.2.8 Submerged Depth | Technical requirements for submerged depth. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|---|
| 5. Athletic team . . . | <ul style="list-style-type: none"> • 11B-206.2.2 Within a Site • 11B-206.4 Spaces and Elements | <p>Scoping for accessible route connecting accessible buildings, facilities, elements, and spaces on the same site.</p> <p>Scoping for accessible route connecting entrances to accessible spaces and elements within the building or facility.</p> |
| 1104B.4.4 Clubrooms. | <ul style="list-style-type: none"> • 11B-201.1 Scope • 11B-222 Dressing, Fitting, and Locker Rooms • 11B-222.1 General | <p>General scoping requirements. Scoping based on use for Dressing, Fitting, and Locker rooms.</p> |
| 1104B.4.5 Sanitary and locker facilities. | <ul style="list-style-type: none"> • 11B-222 Dressing, Fitting, and Locker Rooms • 11B-222.1 General • 11B-213 Toilet and Bathing Facilities • 11B-213.2 Toilet Rooms and Bathing Rooms | <p>Scoping based on use for Dressing, Fitting, and Locker rooms.</p> <p>Scoping for toilet and bathing facilities</p> |
| 1104B.5 Dining, banquet and bar facilities. | N/A | Title only in 2010 CBC. |
| 1. General. | <ul style="list-style-type: none"> • 11B-201.1 Scope • 11B-226 Dining Surfaces and Work Surfaces • 11B-226.1 General | <p>General scoping requirements. Scoping for dining and work surfaces</p> |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | <p>The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file.</p> |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | <p>The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file.</p> |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|-----------------------------------|--|---|
| 2. Entrance. | <ul style="list-style-type: none"> • 11B-206.2.2 Within a Site • 11B-206.4 Entrances | <p>Scoping for accessible route connecting accessible buildings, facilities, elements, and spaces on the same site.</p> <p>Scoping for entrances for buildings or facilities .</p> |
| 3. Raised or sunken areas. | <ul style="list-style-type: none"> • 11B-206.2.5 Restaurants and Cafeterias • 11B-303.5 Warning Curbs, Exception | <p>Scoping for all dining areas, included raised and sunken areas.</p> <p>Scoping for warning curbs and guard or handrails at the open edges of raised or sunken areas.</p> |
| 4. Seating. | <ul style="list-style-type: none"> • 11B-226.1 General • 11B-226.2 Dispersion • 11B-226.3 Dining Surfaces exceeding 34" in height. • 11B-403.5.1 Clear Width, Exception 4 • 11B-902.3 Height, Exception | <p>Scoping for number of wheelchair spaces at dining seating to be 5%.</p> <p>Scoping for dispersion of wheel chair spaces within seating for each type of functional area.</p> <p>Scoping for portion of dining surface of 60" in length</p> <p>Technical requirements for clear width at aisles.</p> <p>Technical requirement for height of dining and work surfaces.</p> |
| 5. Food service aisles. | <ul style="list-style-type: none"> • 11B-403.5.1 Clear Width, Exception 4 • 11B-227.4 Food Service Lines • 11B-904.5 Food Service Lines | <p>Technical requirement for clear width at aisles.</p> <p>Scoping for self-service shelving at food service lines.</p> <p>Technical requirements for food service aisles.</p> |
| 6. Tableware and condiment areas. | 11B-904.5.1 Self-Service Shelves and Dispensing Devices | Technical requirements for dispensing tableware, dishware, condiments, food and beverages. |
| 7. Restrooms | <ul style="list-style-type: none"> • 11B-213 Toilet and Bathing Facilities • 11B-213.2 Toilet Rooms and Bathing Rooms | Scoping for toilet and bathing facilities |
| 8. Food preparation areas. | <ul style="list-style-type: none"> • Chapter 2 – Section 202 • 11B-203.9 Employee Work Areas | <p>Definition of workstation</p> <p>Scoping for access to employee work areas.</p> |
| 1104B.6 Religious facilities. | N/A | Title only in 2010 CBC. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 1104B.6.1. General. | 11B-244 Religious Facilities | Model code has been amended to include scoping for religious facilities. |
| Exception. | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1104B.6.2. Sanctuary. | 11B-244 Religious Facilities | Scoping for religious facilities including various areas within facility. |
| 1104B.6.2.1. Wheelchair seating . . . | 11B-221.2.1.1 General Seating | Scoping for number of wheelchair spaces required. |
| 1104B.6.2.2. Wheelchair access . . . | 11B-206.2.6 Performance Areas | Scoping for direct accessible route to performance and ancillary areas. |
| Exception. In existing buildings . . . | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1104B.6.3. Assembly areas. | <ul style="list-style-type: none"> • 11B-206.4 Spaces and Elements • 11B-206.2.6 Performance Areas | <p>Scoping for accessible routes connecting entrances to accessible spaces and elements within the building or facility.</p> <p>Scoping for direct accessible route to performance and ancillary areas..</p> |
| 1104B.6.4. Classrooms and offices. | 11B-206.4 Spaces and Elements | Scoping for accessible route connecting entrances to accessible spaces and elements within the building or facility. |
| 1104B.6.5. Sanitary facilities. | <ul style="list-style-type: none"> • 11B-213 Toilet and Bathing Facilities • 11B-213.2 Toilet Rooms and Bathing Rooms | Scoping for toilet and bathing facilities |

Section 1105B Accessibility for Group B Occupancies

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| Section 1105B Accessibility for Group B Occupancies | 11B-101.1 General | General scoping for buildings and facilities |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 3 | <ul style="list-style-type: none"> • 11B-303 Changes in Level • 11B-402.2 Components. | <p>Technical requirements for changes in level.</p> <p>Technical requirements for accessible routes</p> |
| 1105B.1 General. | N/A | Title only in 2010 CBC. |
| 1105B.2 Group B occupancies. | 11B-221 Assembly Areas | Based on use as an assembly area Scoping for Assembly Areas will apply. |
| 1105B.3 Office buildings and personal and public service facilities. | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope | Scoping for newly designed, newly constructed and altered portions of existing buildings. |
| 1105B.3.1 Facilities covered. | N/A | Title only in 2010 CBC. |
| 1. All types of . . . business professional offices, . . . | <ul style="list-style-type: none"> • 11B-106.5 Definitions • Section 202 DEFINITIONS • 11B-201.1 Scope | <p>Definition of Place of Public Accommodation.</p> <p>Scoping for newly designed, newly constructed and altered portions of existing buildings.</p> <p>Types of facilities listed covered under this division.</p> |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|--|--|
| 2. All types of sales establishments . . . | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings. Types of facilities listed covered under this division.</p> |
| 3. All personal and public service facilities, . . . | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope • 11B-217.4.6 Hospitals • 11B-231 Judicial Facilities • 11B-232 Detention Facilities and Correctional • 11B-611 Washing Machines and Clothes Dryers | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings. Types of facilities listed covered under this division.</p> <p>Scoping for hospitals</p> <p>Scoping for courtrooms</p> <p>Scoping for detention and correctional facilities.</p> <p>Technical requirements for laundry equipment.</p> |
| 4. . . . areas used for businesses transactions with the public . . . | <ul style="list-style-type: none"> • 11B-707.9.2 Point-of-sale devices at check stands and sales and services counters. • 11B-226 Dining Surfaces and Work Surfaces • 11B-901.1 Scope | <p>Technical requirements for point-of-sale devices at check stands and sales and service counters.</p> <p>Scoping for dining surfaces and work surfaces.</p> <p>Technical requirements for built-in elements.</p> |
| 1105B.3.2 Business and professional offices. | Chapter 2 – Section 202 | Definition of Place of Public Accommodation. |
| 1. Client and visitor areas and office areas, together with related toilet rooms. | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope • 11B-213 Toilet and Bathing Facilities • 11B-213.2 Toilet Rooms and Bathing Rooms | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings.</p> <p>Types of facilities listed in 2010 CBC covered under this division.</p> <p>Scoping for toilet and bathing facilities.</p> |
| 2. Conferences rooms, counseling rooms or cubicles and similar areas. | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings.</p> <p>Types of facilities listed in 2010 CBC covered under this division.</p> |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|---|
| 3. Employee work areas shall have a minimum of 36 inch clear width access . . . | <ul style="list-style-type: none"> • 11B-203.9 Employee Work Areas. • 11B-403 Walking Surfaces • 11B-403.5 Clearances, Exception • 11B-403.5.1 Clear Width | <p>Scoping for employee work areas.</p> <p>Technical requirements for walking surfaces part of an accessible route.</p> <p>Technical requirements for clearances within employee work areas.</p> <p>Technical requirements for clear width of walking surfaces.</p> |
| 4. Professional medical and dental offices . . . | <ul style="list-style-type: none"> • 11B-223.4 Professional Offices of Health Care Providers • 11B-805 Medical Care and Long Term Care Facilities | Scoping for offices of health care providers. |
| 1105B.3.3 Personal and public service facilities. | Chapter 2 – Section 202 | Definition of Place of Public Accommodation. |
| 1. Client and visitor areas and office areas, together with related toilet rooms. | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope • 11B-213 Toilet and Bathing Facilities • 11B-213.2 Toilet Rooms and Bathing Rooms | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings.</p> <p>Types of facilities listed covered under this division.</p> <p>Scoping for toilet and bathing facilities.</p> |
| 2. Employee work areas shall have a minimum of 36 inch clear width access . . . | <ul style="list-style-type: none"> • 11B-203.9 Employee Work Areas. • 11B-403 Walking Surfaces • 11B-403.5 Clearances, Exception • 11B-403.5.1 Clear Width | <p>Scoping for employee work areas.</p> <p>Technical requirements for walking surfaces part of an accessible route.</p> <p>Technical requirements for clearances within employee work areas.</p> <p>Technical requirements for clear width of walking surfaces.</p> |
| 3. Automated teller machines . . . shall be on an accessible route . . . | 11B-206.2.2 Within a Site. | Scoping requirement for an accessible route to connect accessible buildings, facilities, elements and spaces on a site. |
| 1105B.3.4 Public utility facilities. | Chapter 2 – Section 202 | Definition of Place of Public Accommodation. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 1. Office areas, meetings rooms and similar areas . . . | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope • 11B-213 Toilet and Bathing Facilities • 11B-213.2 Toilet Rooms and Bathing Rooms | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings. Types of facilities listed covered under this division.</p> <p>Scoping for toilet and bathing facilities.</p> |
| 2. Public tour areas, . . . | 11B-206.2.2 Within a Site. | Scoping requirement for an accessible route to connect accessible buildings, facilities, elements and spaces on a site. |
| Exception 1. Facilities located in operational areas. . . | 11B-203.5 Machinery Spaces | Scoping for accessible route at machinery spaces. |
| Exception 2. . . . unreasonable hardship, . . | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 3. Visitor overlook facilities . . . | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope • 11B-213 Toilet and Bathing Facilities • 11B-213.2 Toilet Rooms and Bathing Rooms | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings. Types of facilities listed in the 2010 CBC covered under this division.</p> <p>Scoping for toilet and bathing facilities.</p> |
| 4. Where public parking is provided . . . | <p>11B-208 Parking Spaces</p> <p>11B-502 Parking Spaces</p> | <p>Scoping requirements for parking.</p> <p>Technical requirements for accessible parking.</p> |
| 1105B.3.5 Police department, law enforcement, Fire Department facilities and courtrooms. | <ul style="list-style-type: none"> • 11B-230.1 Judicial Facilities • 11B-232 Detention Facilities and Correctional Facilities | Scoping for judicial and correctional facilities. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|---|
| 1. Office areas, conference rooms, . . . | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope • 11B-231.4 Visiting Areas • 11B-213 Toilet and Bathing Facilities • 11B-213.2 Toilet Rooms and Bathing Rooms | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings.</p> <p>Scoping for visiting areas.</p> <p>Scoping for toilet and bathing facilities.</p> |
| 2. Detention area visitor rooms . . . | 11B-232.5 Visiting Areas | Scoping for visiting areas. |
| 3. At least one detention cell . . . | <ul style="list-style-type: none"> • 11B-232 Detention Facilities and Correctional Facilities • 11B-807.2.4 Toilet and Bathing Facilities | <p>Scoping requirements for detention facilities</p> <p>Technical requirements for toilet and bathing facilities provided as part of a cell.</p> |
| 4. Courtroom areas, . . . | <ul style="list-style-type: none"> • 11B-231.1 General • 11B-808.4 Judges' Benches and Courtroom Stations. • 11B-902 Dining Surfaces and Work Surfaces | <p>Scoping requirements for judicial facilities.</p> <p>Technical requirements for judges' benches and courtroom stations.</p> <p>Technical requirements for work surfaces.</p> |
| 1105B.3.6 Miscellaneous general standards. | N/A | Title only in 2010 CBC. |
| 1. Circulation aisles and pedestrian ways . . . | <ul style="list-style-type: none"> • 11B-403 Walking Surfaces • 11B-403.1 General • 11B-403.5 Clearances • 11B-403.5.1 Clear Width | <p>Technical requirements for walking surfaces as part of an accessible route.</p> <p>Technical requirements for clear width.</p> |
| 2. Storage areas . . . | <ul style="list-style-type: none"> • 11B-225.2 Storage • 11B-223.3 Self-Service Storage Facilities | <p>Scoping requirements for general storage uses.</p> <p>Scoping for self-service storage facilities.</p> |

Section 1106B Accessibility for Group E Occupancies

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|--|---|
| 1106B.1 General. | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope | Scoping for newly designed, newly constructed and altered portions of existing buildings. |
| Exception 1. | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for, technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2. | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1106B.2 Laboratory rooms. . . . shall have at least one and at least 5 percent of all workstations accessible . . . | <ul style="list-style-type: none"> • 11B-226 Dining Surfaces and Work Surfaces • 11B-226.1 General • 11B-226.2 Dispersion • 11B-805.7 Built-in Cabinets and Work Surfaces. Exception 2. 11B-902 Dining Surfaces and Work Surfaces • 11B-902.1 General • 11B-902.2 Clear Floor or Ground Space • 11B-902.3 Height | <p>Scoping for number and dispersion of work surfaces.</p> <p>Detailed scoping for laboratory workstations requiring 5 percent but not less than one to be accessible.</p> <p>Technical requirements for work surfaces.</p> |
| Exception. | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|---|
| 1106B.3 Teaching facility cubicles, study carrels, etc. | <ul style="list-style-type: none"> • 11B-226 Dining Surfaces and Work Surfaces • 11B-226.1 General • 11B-226.2 Dispersion • 11B-902 Dining Surfaces and Work Surfaces • 11B-902.1 General • 11B-902.2 Clear Floor or Ground Space • 11B-902.3 Height | <p>Scoping for number and dispersion of work surfaces.</p> <p>Technical requirements for work surfaces.</p> |
| 1106B.4 Library general use areas. | N/A | Title only in 2010 CBC. |
| 1. General. | <ul style="list-style-type: none"> • 11B-201.1 Scope • 11B-225.2 Storage • 11B-227.3 Counters | <p>General scoping for building and facility accessibility</p> <p>Scoping for storage.</p> <p>Scoping for counters.</p> |
| 2. Open book stacks. | 11B-225.2.3 Library Book Stacks | Technical requirements for book shelves. |
| 3. Height of book shelves. | <ul style="list-style-type: none"> • 11B-308.3 Side Reach • 11B-308.3.1 Unobstructed, Exception 3 | Technical requirements for book shelves. |
| 4. Card catalogs and magazine displays. | <ul style="list-style-type: none"> • 11B-308.2 Forward Reach • 11B-308.3 Side Reach | Technical requirements for reach ranges. |
| 5. Reading and study areas. | <ul style="list-style-type: none"> • 11B-226 Dining Surfaces and Work Surfaces • 11B-226.1 General • 11B-226.2 Dispersion • 11B-902 Dining Surfaces and Work Surfaces • 11B-902.1 General • 11B-902.2 Clear Floor or Ground Space • 11B-902.3 Height | <p>Scoping for 5 percent of workstations to comply with requirements.</p> <p>Dispersion of work surfaces.</p> <p>Technical requirements for work surfaces</p> |
| 6. Check-out areas. | 11B-904.3.1 Check-Out Aisles | Technical requirements for check-out aisles. |

Section 1107B Factories and Warehouses

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|---|
| Factories and warehouses..... | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope • 11B-206.2.3 Multi-Story Buildings and Facilities | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings.</p> <p>Scoping for accessible route in Multi-Story Buildings and Facilities</p> |
| Exception | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for, technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1107B.1 Factories. | N/A | Title only in 2010 CBC. |
| 1. Major or principle floor areas shall be made accessible. | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope • 11B-203.9 Employee Work Areas | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings.</p> <p>Scoping for accessible route in employee work areas.</p> |
| 2. Office areas shall be made accessible. | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope • 11B-203.9 Employee Work Areas | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings.</p> <p>Scoping for accessible route in employee work areas.</p> |
| 3. Sanitary facilities serving these facilities . . . | <ul style="list-style-type: none"> • 11B-213 Toilet and Bathing Facilities • 11B-213.2 Toilet Rooms and Bathing Rooms | Scoping for toilet and bathing facilities. |
| 1107B.2 Warehouses. | N/A | Title only in 2010 CBC. |
| 1. Miscellaneous warehousing areas . . . | 11B-206.2.3 Multi-Story Buildings and Facilities | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings.</p> <p>Scoping for accessible route in Multi-Story Buildings and Facilities</p> |
| 2. Office areas shall be made accessible. | 11B-203.9 Employee Work Areas | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings.</p> <p>Scoping for accessible route in employee work areas.</p> |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 3. Sanitary facilities serving these facilities . . . | <ul style="list-style-type: none"> • 11B-213 Toilet and Bathing Facilities • 11B-213.2 Toilet Rooms and Bathing Rooms | Scoping for toilet and bathing facilities. |

Section 1108B Accessibility for Group H Occupancies

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 1108B.1 General. | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope | Scoping for newly designed, newly constructed and altered portions of existing buildings. |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1108B.2 Accessible sanitation facilities. | <ul style="list-style-type: none"> • 11B-213 Toilet and Bathing Facilities • 11B-213.2 Toilet Rooms and Bathing Rooms | Scoping for toilet and bathing facilities. |
| 1108B.3 Accessible routes. | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope | Scoping for newly designed, newly constructed and altered portions of existing buildings. |
| 1108B.4 Accessible floors and levels. | <ul style="list-style-type: none"> • 11B-206.2.3 Multi-Story Buildings and Facilities • 11B-402 Accessible Routes | Scoping for accessible route in Multi-Story Buildings and Facilities Technical requirements for accessible routes. |
| 1108B.5 Employee work areas. | 11B-203.9 Employee Work Areas | Scoping for accessible route in employee work areas. |
| 1108B.6 Accessible facilities covered . . . | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope | Scoping for newly designed, newly constructed and altered portions of existing buildings. |

Section 1109B Accessibility for Group I Occupancies

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 1109B.1 General. | 11B-223 – Medical Care and Long Term Care Facilities | Scoping for Medical Care and Long Term Care Facilities |
| Exception | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1109B.2 Entrance. | <ul style="list-style-type: none"> • 11B-209 Medical and Long Term Care Facilities • 11B-503 Passenger Drop-Off and Loading Zone | <p>Scoping for accessible entrance with passenger loading zone.</p> <p>Technical requirements for passenger drop-off and loading zones.</p> |
| 1109B.3 Patient bedrooms and toilet rooms. | <ul style="list-style-type: none"> • 11B-223 Medical Care and Long term Care Facilities • 11B-805 Medical Care and Long term Care Facilities • 11B-805.2.4 Toilet and Bathing Rooms | <p>Scoping for patient bedrooms.</p> <p>Technical requirements for patient bedrooms.</p> <p>Technical requirements for patient toilet rooms.</p> |
| 1. Long-term care facilities . . . | 11B-223.3 Long Term Care Facilities | Scoping for number of accessible rooms in long term care facilities. |
| 2. General purpose hospitals . . . | 11B-223.2.1 Facilities Not Specializing in Treating Conditions That Affect Mobility. | Scoping for number of accessible rooms in facilities not specializing in treating conditions that affect mobility and general hospital facilities. |
| 3. Hospitals and rehabilitation facilities that specialize in treating conditions affecting mobility . . . | 11B-223.2.2 Facilities Specializing in Treating Conditions That Affect Mobility | Scoping for number of accessible rooms in facilities specializing in treating conditions that affect mobility. |
| Exception 1. | 11B-223.1.1.1 Area Alterations | Scoping for area alterations. |
| Exception 2. | 11B-223.1.1.2 Individual Alterations | Scoping for individual alterations. |
| 1109B.4 Patient bedroom areas. | N/A | Title only in 2010 CBC. |
| 1. Each bedroom shall have a turning space . . . | 11B-805.2.3 Turning Space | Technical requirements for turning space in patient bedroom. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 2. Each bedroom shall have a minimum clear floor space . . . | 11B-805.2.2 Beds | Technical requirements for clear space along the full length of bed. |
| 3. Each bedroom shall have an accessible door . . . | 11B-404.3 Manual Doors, Doorways, and Gates | Technical requirements for doors, doorways and gates. |
| 1109B.5 Patient toilet rooms and bathing facilities. | 11B-805.2.4 Toilet and Bathing Rooms | Technical requirements for patient toilet rooms. |
| 1109B.6 Diagnostic and treatment areas. | 11B-805.4 Examination, Diagnostic and Treatment Rooms. | Technical requirements for examination, diagnostic and treatment rooms. |
| 1109B.7 Waiting areas, offices and sanitary facilities. | <ul style="list-style-type: none"> • 11B-213 Toilet and Bathing Facilities • 11B-213.2 Toilet Rooms and Bathing Rooms | Scoping for toilet and bathing facilities. |
| 1109B.8 Offices and suites. | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201.1 Scope • 11B-402 Accessible Routes • 11B-203.9 Employee Work Areas • 11B-805.7 Built-in Cabinets and Work Surfaces | <p>Scoping for newly designed, newly constructed and altered portions of existing buildings.</p> <p>Technical requirements for accessible routes.</p> <p>Scoping for accessible route in employee work areas.</p> <p>Technical requirements for built-in cabinets and work surfaces.</p> |

Section 1110B Accessibility for Group M Occupancies

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--------------------------------------|---|---|
| 1110B.1 Sales. | 11B-227 Sales and Service | Scoping for sales and service facilities. |
| 1110B.1.1 General areas. | <ul style="list-style-type: none"> • 11B-227 Sales and Service • 11B-227.1 General | Scoping for sales and service facilities. |
| Exception 1 | Not carried forward | This provision would lessen the level of accessibility provided by the 2010 ADAS. |
| Exception 2 | Not carried forward | This provision would lessen the level of accessibility provided by the 2010 ADAS. |
| 1110B.1.2 Work areas. | <ul style="list-style-type: none"> • 11B-227.2 Check-Out Aisles • 11B-904 Check-Out Aisles and Sales and Service Counters • 11B-203.9 Employee Work Areas | <p>Scoping for check-out aisles.</p> <p>Technical requirements for check-out aisles and sales and service counters.</p> <p>Scoping for accessible route in employee work areas.</p> |
| 1110B.1.3 Check stands. | <ul style="list-style-type: none"> • 11B-216.11 Check-Out Aisles • 11B-227.2 Check-Out Aisles • 11B-904.3 Check-Out Aisles • Table 11B-227.2 Check-Out Aisles | <p>Scoping for ISA at check-out aisle.</p> <p>Scoping for check-out aisles.</p> <p>Technical requirements for check-out aisles.</p> <p>Requirement for number of accessible check-out aisles.</p> |
| 1110B.1.4 Point-of-sale machines. | <ul style="list-style-type: none"> • 11B-220.2 Point-of-Sale Devices • 11B-707 Automatic Teller Machine, and Fare Machines and Point-of-Sale Devices | <p>Scoping for point-of-sale devices.</p> <p>Technical requirements for automatic teller machine, and fare machines and point-of-sale devices.</p> |
| 1110B.1.5 Turnstiles. | 11B-404.2.1 Revolving Doors, Gates, and Turnstiles. | Technical requirements for revolving doors, gates, and turnstiles. |
| 1110B.1.6 Theft prevention barriers. | 11B-206.8 Security Barriers | Scoping for security barriers. |
| 1. Each entrance and exit . . . | <ul style="list-style-type: none"> • 11B-206.4 Entrances • 11B-207 Accessible Means of Egress | <p>Scoping for accessible entrances.</p> <p>Scoping for accessible means of egress.</p> |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|--|--|
| 2. Shopping cart barriers located . . . | <ul style="list-style-type: none"> • 11B-206.8 Security Barriers • 11B-404.2.4.2 Doorways without Doors or Gates, Sliding Doors, and Folding Doors | <p>Scoping for security barriers.</p> <p>Technical requirements for doorways without doors or gates, sliding doors, and folding doors including openings.</p> |
| 3. Where gates are used . . . | <ul style="list-style-type: none"> • 11B-206.4 Entrances • 11B-207 Accessible Means of Egress • 11B-404.2.4.2 Doorways without Doors or Gates, Sliding Doors, and Folding Doors | <p>Scoping for accessible entrances.</p> <p>Scoping for accessible means of egress</p> <p>Technical requirements for doorways without doors or gates, sliding doors, and folding doors including openings.</p> |
| 4. Where a clear unobstructed opening . . . | Table 11B-404.2.4.1 Maneuvering Clearances at Manual Swinging Doors and Gates | Technical requirements for clearances at manual swinging doors and gates. |
| 5. Where a gate is used, the level area . . . | Table 11B-404.2.4.1 Maneuvering Clearances at Manual Swinging Doors and Gates | Technical requirements for clearances at manual swinging doors and gates. |
| 6. Where a gate is used, the bottom . . . | 11B-404.2.10 Door and Gate Surfaces. | Technical requirements for door and gate surfaces. |
| 7. The path of travel to and through . . . | <ul style="list-style-type: none"> • 11B-307.5 Required Clear Width • 11B-403.5.1 Clear Width | <p>Technical requirements for obstructions within accessible route.</p> <p>Technical requirements for clear width.</p> |
| 8. Interior and exterior traffic barriers . . . | <ul style="list-style-type: none"> • 11B-307.5 Required Clear Width • 11B-403.5.1 Clear Width | <p>Technical requirements for obstructions within accessible route.</p> <p>Technical requirements for clear width.</p> |
| 1110B.2 Miscellaneous general standards. | N/A | Title only in 2010 CBC. |
| 1110B.2.1 Circulation. | <ul style="list-style-type: none"> • 11B-225.2.2 Self-Service Shelving • 11B-403.5.1 Clear Width | <p>Scoping for self-service shelving.</p> <p>Technical requirements for clear width.</p> |
| 1110B.2.2 Storage areas. | <ul style="list-style-type: none"> • 11B-206.4 Entrances • 11B-225 Storage | <p>Scoping for accessible entrances.</p> <p>Scoping for storage.</p> |

Section 1111B Accessibility for Group R Occupancies

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|--|--|
| 1111B.1 General. | 11B-201.1, as excepted by 11B-203.8 | Scoping for residential facilities. |
| Exception | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1111B.2 Public and common use rooms or areas. | <ul style="list-style-type: none"> • 11B-206 Accessible Routes • 11B-402 Accessible Routes • 11B-214 Washing Machines and Clothes Dryers • 11B-611 Washing Machines and Clothes Dryers | <p>Scoping for accessible routes.</p> <p>Technical requirements for accessible routes.</p> <p>Scoping for washing machines and clothes dryers.</p> <p>Technical requirements for washing machines and clothes dryers.</p> |
| Exception: Where elevators are not required . . . | <ul style="list-style-type: none"> • 11B-203.8 Residential Facilities • 11B-206.2.3 Multi-Story Buildings and Facilities, Exception 4. | <p>Scoping for common use areas not on accessible route.</p> <p>Scoping for common use areas not on accessible route in multi-story buildings.</p> |
| 1111B.3 Recreational facilities. | <ul style="list-style-type: none"> • 11B-206.2.2 Within a Site • 11B-1001 General | <p>Scoping for accessible routes within a site.</p> <p>Technical requirements for recreational facilities including swimming pools.</p> |
| 1111B.4 Hotels, motels, inns, dormitories, resorts, homeless shelters, halfway houses, transient group homes and similar places of transient lodging. | <ul style="list-style-type: none"> • 11B-224 Transient Lodging Guest Rooms • 11B-224.1.1 Alterations | <p>Scoping for transient lodging accommodations .</p> <p>Scoping for alterations.</p> |
| 1111B.4.1 Available range of accommodations. | <ul style="list-style-type: none"> • 11B-224.1.3 Range of Accommodations • 11B-224.5 Dispersion | Scoping for range of accommodations in transient lodging facilities. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|--|--|
| 1111B.4.2 Guest rooms and suites. | <ul style="list-style-type: none"> • 11B-224.2 Guest Rooms with Mobility Features • 11B-224.4 Guest rooms with Communication Features • 11B-806.2.4 Toilet and Bathing Facilities | <p>Scoping number of rooms with mobility and communication features.</p> <p>Technical requirements for toilet and bathing facilities part of a guest room.</p> |
| 1111B.4.2.1 Spaces. | <ul style="list-style-type: none"> • 11B-201 Application • 11B-201 Accessible Routes | Scoping for required accessible spaces within a guest room. |
| 1. The living area: | 11B-806.2.1 Living and Dining Areas | Technical requirements for living and dining areas. |
| 2. The dining area: | 11B-806.2.1 Living and Dining Areas | Technical requirements for living and dining areas. |
| 3. At least one sleeping area: | 11B-806.2.3 Sleeping Areas | Technical requirements for sleeping areas. |
| 4. Patios, terraces or balconies: | 11B-806.2.2 Exterior Spaces | Technical requirements for exterior space including patios, terraces and balconies. |
| 5. Where full bathrooms are provided, at least . . . | 11B-806.2.4 Toilet and Bathing Facilities | Technical requirements for toilet and bathing facilities part of a guest room. |
| 6. Where only half baths are provided, at . . . | 11B-806.2.4 Toilet and Bathing Facilities | Technical requirements for toilet and bathing facilities part of a guest room. |
| 7. Carports, Garages, or Parking Spaces | 11B-208 Parking | Scoping for parking. |
| 1111B.4.2.2 Accessible route. | <ul style="list-style-type: none"> • 11B-206.4 Entrances • 11B-806.2 Guest Rooms with Mobility Features | <p>Scoping for accessible entrances.</p> <p>Technical requirement for accessible feature.</p> |
| 1111B.4.2.3 Doors. | N/A | Title only in 2010 CBC. |
| 1111B.4.2.3.1 Doors into and within covered rooms and suites. | <ul style="list-style-type: none"> • 11B-206.4 Entrances • 11B-206.5 Doors, Doorways and Gates. | Scoping for accessible entrances. |
| 1111B.4.2.3.2 Doors into and within all other rooms and suites. | <ul style="list-style-type: none"> • 11B-224.1.2 Guest Room Doors and Doorways • 11B206.5.3 Transient Lodging Facilities | Scoping for door and doorways in guest rooms not required to have mobility features. |
| 1111B.4.2.4 Alterations in existing facilities. | 11B-224.1.1 Alterations | Scoping for alterations. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|--|---|
| 1111B.4.3 Access to beds. | <ul style="list-style-type: none"> • 11B-224.3 Beds • 11B-806.2.3 Sleeping Areas • 11B-806.2.3.1 Personal Lift Device Floor Space | <p>Scoping requirements for access to beds.</p> <p>Technical requirements for access to beds.</p> <p>Technical requirements for personal lift device floor space.</p> |
| 1111B.4.4 Kitchens, kitchenettes or wet bar facilities. | <ul style="list-style-type: none"> • 11B-212 Kitchens, Kitchenettes and Wet Bars. • 11B-806.2.5 Kitchens, Kitchenettes and Wet Bars. | <p>Scoping for kitchens, kitchenettes and wet bars.</p> <p>Technical requirements for kitchens, kitchenettes and wet bars.</p> |
| 1111B.4.5 Visible alarms, notification devices and telephones for persons with hearing impairments. | <ul style="list-style-type: none"> • 11B224.4 Guest Rooms with Communication Features • 11B-806.3 Guest Rooms with Communication Features | <p>Scoping requirements for visible alarms, notification devices and telephones.</p> <p>Technical requirements for visible alarms, notification devices and telephones.</p> |
| 1111B.4.5.1 Visible alarms. | 11B-806.3.1 Alarms. | Technical requirements for alarms. |
| 1111B.4.5.2 Visual notification devices. | 11B-806.3.2 Notification Devices | Technical requirements for notification devices. |
| 1111B.4.5.3 Telephones. | 11B-806.3.2 Notification Devices | Technical requirements for notification devices including telephones. |
| 1111B.4.6 Bathrooms in hotels, motels, inns, dormitories, resorts, homeless shelters, halfway houses, transient group homes and similar places of transient lodging. | 11B-806.2.4. | Technical requirements for toilet and bathing facilities. |
| 1. Doors. | 11B-603.2.3 Door Swing | Technical requirements for door swing into toilet room. |
| 2. Clear floor space. | 11B-603.2.1 Turning Space | Technical Requirements for turning space within the toilet and bathing facility. |
| 3. Water closets. | 11B-604.3 Clearance | Technical requirements for clearance around water closets. |
| 4. Lavatory and mirrors. | <ul style="list-style-type: none"> • 11B-606 Lavatories and Sinks • 11B-603.3 Mirrors | <p>Technical requirements for lavatories and sinks.</p> <p>Technical requirements for mirrors.</p> |
| 5. Controls and dispensers. | <ul style="list-style-type: none"> • 11B-309 Operable Parts • 11B-603.5 Accessories | <p>Technical requirements for operable parts</p> <p>Technical requirements for accessories</p> |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 6. Bathing and shower facilities. | <ul style="list-style-type: none"> • 11B-607 Bathtubs • 11B-608 Shower Compartments • 11B-806.2.4 Toilet and Bathing Facilities | Technical requirements for bathtubs and shower compartments |
| 7. Toilet facilities. | <ul style="list-style-type: none"> • 11B-603 Toilet and Bathing Rooms • 11B-604 Water Closets and Toilet Compartments • 11B-806.2.4 Toilet and Bathing Facilities | Technical requirements for toilet rooms |
| <p>Hotel and motel bathrooms beyond those specified in Section 1111B.4 shall provide the following features:</p> <p>1. All bathroom fixtures shall be in a location that allows a person using a wheelchair measuring 30 inches by 48 inches (762 mm by 1219 mm) to touch the wheelchair to any lavatory, urinal, water closet, tub, sauna, shower stall and any other similar sanitary installation, if provided.</p> <p>2. All bathroom entrance doors shall have a clear opening width of 32 inches (813 mm) and shall be either sliding doors or shall be hung to swing in the direction of egress from the bathroom.</p> | <ul style="list-style-type: none"> • 11B-224.1.6 Guest Room Toilet and Bathing Rooms • 11B-213.2 Toilet Rooms and Bathing Rooms • 11B-603.6 Guest Room Toilet and Bathing Rooms <p>11B-224.1.2 Guest Room Doors and Doorways</p> | <p>Scoping for toilet and bathing rooms in guest rooms not required to provide mobility features.</p> <p>Technical requirements for toilet and bathing rooms in guest rooms not required to provide mobility features.</p> <p>Technical requirements for clear width at door for guest rooms not required to have mobility features.</p> |
| 1111B.4.7 Storage areas. | 11B-224.6 Storage | Scoping for fixed or built-in storage |
| 1111B.4.8 Dormitory rooms. | 11B-224.1.2 Guest Room Doors and Doorways | Technical requirements for clear width at door for guest rooms not required to have mobility features. Adaptable feature language not carried forward, those features are in kitchens and bathrooms, not located in dorm room. |
| 1111B.5 Buildings and complexes containing publicly funded dwelling units. | N/A | Title only in 2010 CBC |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|----------------------|---|--|
| 1111B.5.1 General. | <ul style="list-style-type: none"> <li data-bbox="581 191 959 222">• 11B-233 Residential Facilities <li data-bbox="581 281 889 312">• 11B-233.3.4 Alterations | Scoping for publicly funded facilities containing residential dwelling units |

Section 1112B Reserved

Section 1113B Reserved

Section 1114B Facility Accessibility

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|----------------------------------|--|---|
| 1114B.1 Design and construction. | 11B-201.1 Scope | General scoping for building and facility accessibility |
| 1114B.1.1 General. | 11B-201.1 Scope | General scoping for building and facility accessibility |
| Chapter 11B, Accessibility | 11B-201.1 Scope | General scoping for building and facility accessibility |
| Entrances | 11B-206.4 Entrances | General scoping for building and facility accessibility |
| Doors | 11B-206.5 Doors, Doorways and Gates | General scoping for building and facility accessibility |
| Corridors | 11B-206 Accessible Routes | General scoping for building and facility accessibility |
| Stairways | 11B-210 Stairways | General scoping for building and facility accessibility |
| Ramps | 11B-206 Accessible Routes | General scoping for building and facility accessibility |
| Aisles | 11B-206 Accessible Routes | General scoping for building and facility accessibility |
| Walks and Sidewalks | 11B-206 Accessible Routes | General scoping for building and facility accessibility |
| Hazards | 11B-206 Accessible Routes | General scoping for building and facility accessibility |
| Elevators | 11B-206.6 Elevators | General scoping for building and facility accessibility |
| Platform (Wheelchair) Lifts | 11B-206.7 Platform Lifts | General scoping for building and facility accessibility |
| Alarms | 11B-215 Fire Alarm Systems | General scoping for building and facility accessibility |
| Bathing and Toilet Facilities | 11B-213 Toilet Facilities and Bathing Facilities | General scoping for building and facility accessibility |
| Signs and Identification | 11B-216 Signs | General scoping for building and facility accessibility |
| Detectable Warnings | 11B-705 Detectable Warnings | General scoping and technical requirements for building and facility accessibility – detectable warning |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|---|
| Other Building Components | <ul style="list-style-type: none"> • 11B-205 Operable Parts • 11B-211 Drinking Fountains • 11B-212 Kitchens, Kitchenettes and Sinks • 11B-217 Telephones • 11B-220 Automatic Teller Machines and Fare Machines • 11B-222 Dressing, Fitting and Locker Rooms | General scoping for building and facility accessibility |
| 1114B.1.2 Accessible route of travel. | <ul style="list-style-type: none"> • 11B-206 Accessible Routes • 11B-402 Accessible Routes | Scoping and technical requirements for accessible routes |
| Exception: Where an elevator is provided . . . | 11B-206.6 Elevators | Scoping for elevators – where more than one elevator is provided, all elevators shall be accessible |
| 1114B.1.3 Primary entry access. | <ul style="list-style-type: none"> • 11B-206.4 Entrances • 11B-206.5.5 Exterior Ground Floor Exit Doors | Scoping for entrances and exterior ground floor exit doors |
| 1114B.1.4 Signs. | 11B-216 Signs | Scoping for signs |
| 1114B.1.5 Adaptable dwelling units. | 11B-206.4.6 Residential Dwelling Unit Primary Entrance | Scoping for primary entrances at residential dwelling units |
| 1114B.2 Egress and areas of refuge. | 11B-207 Accessible Means of Egress | Scoping for accessible means of egress |
| 1114B.2.1 General. | 11B-207 Accessible Means of Egress | Scoping for accessible means of egress – reference to Chapter 10, Section 1007 |
| 1114B.2.2 Alarms/emergency warning systems/accessibility. | 11B-215 Fire Alarm Systems | Scoping for fire alarm systems – subsection references to Chapter 9, Sections 907.5.2.1 and 907.5.2.3 |

Section 1115B Bathing and Toilet Facilities (Sanitary Facilities)

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 1115B.1 General. | <ul style="list-style-type: none"> • 11B-213.2 Toilet Rooms and Bathing Rooms • 11B-603.2 Clearances | General scoping and clearance requirements for toilet and bathing facilities |
| Exception: In existing buildings and facilities . . . | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1115B.1.1 Separate and unisex facilities. | 11B-213.2 Toilet Rooms and Bathing Rooms | General scoping for toilet and bathing facilities |
| 1115B.1.2 Where used by children. | 11B-604.9 Water Closets and Toilet Compartments for Children's Use | General scoping for toilet and bathing facilities used by children |
| 1115B.2 Bathing and shower facilities. | 11B-213.3.6 Bathing Facilities | General scoping for bathing facilities |
| 1115B.3 Toilet facilities. | 11B-604.1 General | Technical requirements for toilet facilities |
| 1115B.3.1 Multiple-accommodation toilet facilities. | 11B-213.2 Toilet Rooms and Bathing Rooms | Scoping for multiple-accommodation toilet facilities |
| 1. Wheelchair clearance. | 11B-603.2 Clearances | Technical requirements for turning space |
| 2. Clear floor space at fixtures. | 11B-603.2 Clearances | Technical requirements for overlap and door swing |
| 3. Accessible fixtures. | <ul style="list-style-type: none"> • 11B-213.3.2 Water Closets • 11B-213.3.4 Lavatories | Scoping for water closets and lavatories |
| 4. Accessible water closet compartment. | 11B-604.8.1 Toilet Compartments | Technical requirements for accessible compartment within multiple-accommodation toilet facilities |
| 4.1. The compartment shall be . . . 60 inches wide. | 11B-604.8.1.1 Size | Technical requirement for width of compartment |
| 4.2. If the compartment has a side-opening door . . . | <ul style="list-style-type: none"> • 11B-604.8.1.1.1 Maneuvering Space with In-Swinging Door • 11B-604.8.1.1.2 Maneuvering Space with Side-Opening Door | Technical requirement for maneuvering space in front of water closet in a compartment with a side-opening door |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|--|---|
| 4.3. If the compartment has an end-opening door . . . | <ul style="list-style-type: none"> • 11B-604.8.1.1.1 Maneuvering Space with In-Swinging Door • 11B-604.8.1.1.3 Maneuvering Space with End-Opening Door | Technical requirement for maneuvering space in front of water closet in a compartment with an end-opening door |
| 4.4. The water closet compartment shall . . . | 11B-604.8.1.2 Doors 11B-604.8.1.2 Exception | Technical requirements for doors Model code amended to add technical requirement for 34" clear at in-swinging side-opening doors |
| 4.5. The inside and outside of the compartment door . . . | 11B-604.8.1.2 Doors | Technical requirements for doors |
| 5. Large toilet rooms. | <ul style="list-style-type: none"> • 11B-213.3.1 Toilet Compartments • 11B-604.8.2 Ambulatory Accessible Compartments | Scoping and technical requirements for ambulatory accessible compartments within multiple-accommodation toilet facilities |
| 6. Interior surfaces. | 11B-302 Floor or Ground Surfaces | Technical requirement for floors within toilet facilities |
| 1115B.3.2 Single-accommodation toilet facilities. | 11B-213.2 Toilet Rooms and Bathing Rooms | Scoping for single-accommodation toilet facilities |
| 1. Wheelchair clearance. | 11B-603.2 Clearances | Technical requirements for turning space |
| 2. Clear floor space at fixtures. | 11B-603.2 Clearances | Technical requirements for overlap and door swing |
| 3. Accessible water closet. | <ul style="list-style-type: none"> • 11B-213.3.2 Water Closets • 11B-604.3.1 Size | Scoping and technical requirements for water closets |
| 4. Accessible route. | <ul style="list-style-type: none"> • 11B-213.2 Toilet Rooms and Bathing Rooms • 11B-603.2 Clearances | Scoping and technical requirement for accessible route |
| 5. Interior surfaces. | 11B-302 Floor or Ground Surfaces | Technical requirement for floors within toilet facilities |
| 6. Accessible lavatory. | 11B-213.3.4 Lavatories | Scoping requirement for lavatory |
| 7. Privacy latch. | 11B-213.2.1 Unisex (Single-Use or Family) Toilet and Unisex Bathing Rooms | Scoping requirement for privacy latch |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|---|
| Exception: In an existing building, a single-accommodation toilet facility . . . | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for, technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1115B.4 Accessible fixtures. | 11B-213.3 Plumbing Fixtures and Accessories | General scoping for accessible toilet and bathing facilities fixtures |
| 1115B.4.1 Accessible water closets. | 11B-213.3.2 Water Closets | General scoping for water closets |
| 1. The centerline of the water closet . . . | <ul style="list-style-type: none"> • 11B-604.2 Location • 11B-604.3 Clearance | Technical requirements for centerline and clearances at water closets |
| 2. Provide clear floor space . . . | 11B-604.3 Clearance | Technical requirements for clearances at water closets |
| 2.1. Where a water closet is not within a water closet compartment . . . | 11B-604.3.1 Size | Technical requirements for size of clearance at water closets not located within accessible compartments |
| 2.2. Where a wall mounted water closet is installed within . . . | 11B-604.8.1.1 Size | Technical requirements for size of clearance at water closets located within accessible compartments |
| 2.3. Where a water closet is installed within an accessible . . . | 11B-604.8.1.1.1 Maneuvering Space with In-Swinging Door | Technical requirements for maneuvering space at compartments with in-swinging doors |
| Exception: An adjacent fixture at the rear wall . . . | 11B-604.3.2 Overlap Exception | Exception for adjacent fixture at the rear wall applicable in residential dwelling units only |
| 3. Grab bars for . . . | <ul style="list-style-type: none"> • 11B-604.5 Grab Bars • 11B-604.8.1.5 Grab Bars • 11B-604.8.2.3 Grab Bars | Scoping for grab bars in accessible compartments and ambulatory accessible compartments. |
| 3.1. Side wall | 11B-604.5.1 Side Wall | Technical requirements for side wall grab bars |
| 3.2. Rear wall | 11B-604.5.2 Rear Wall | Technical requirements for rear wall grab bars |
| 4. The height of accessible water closets . . . | 11B-604.4 Seats | Technical requirements for toilet seats |
| Exception: A 3-inch high seat . . . | 11B-604.4 Exception | Exception permitted only in alterations |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|--|--|
| 5. Controls shall be operable . . . | 11B-604.6 Flush Controls | Technical requirements for flush controls |
| 6. See Section 1134A.7 for additional requirements . . . | N/A | Requirements for residential dwelling units located in 2013 CBC, Chapter 11B |
| 7. Automatic springs to lifted position . . . | N/A | Not addressed by 2010 ADAS |
| 1115B.4.2 Accessible urinals. | 11B-213.3.3 Urinals | General scoping for urinals |
| 1. Urinals shall be . . . | 11B-605.2 Height and Depth | Technical requirements for urinal height and depth |
| 2. Flush controls . . . | 11B-605.4 Flush Controls | Technical requirements for flush controls at urinals |
| 3. Where urinals are provided . . . | 11B-605.3 Clear Floor Space | Technical requirement for clear floor space at urinals |
| 1115B.4.3 Accessible lavatories. | 11B-213.3.4 Lavatories | General scoping for lavatories |
| 1. Faucet controls and . . . | 11B-606.4 Faucets | Technical requirements for controls for faucets |
| 2. Lavatories, when located adjacent to . . . | <ul style="list-style-type: none"> • 11B-606.2 Clear Floor Space • 11B-606.3 Height • 11B-606.6 Adjacent Side Wall or Partition | Technical requirements for height, location and toe and knee clearance |
| 3. A clear floor space 30 inches . . . | <ul style="list-style-type: none"> • 11B-306 Knee and Toe Clearance • 11B-606.2 Clear Floor Space | Technical requirements for toe and knee clearance and clear floor space |
| 4. Hot water and drain pipes . . . | 11B-606.5 Exposed Pipes and Surfaces | Technical requirements for exposed pipes and surfaces beneath lavatories |
| 1115B.4.4 Accessible showers. | 11B-213.3.6 Bathing Facilities | General scoping for showers |
| 1115B.4.4.1 Size and clearances. | 11B-608.2 Size and Clearances for Shower Compartments | General scoping for shower compartments |
| 1. Roll-in shower . . . | 11B-608.2.2 Standard Roll-In Type Shower Compartment | Technical requirements for standard roll-in type shower compartments |
| 2. Alternate roll-in shower 60 inches minimum in width . . . | 11B-608.2.3 Alternate Roll-In Type Shower Compartment | Technical requirements for alternate roll-in type shower compartments |
| 3. Alternate roll-in shower with optional enclosure . . . | <ul style="list-style-type: none"> • 11B-608.2.3 Alternate Roll-In Type Shower Compartment • 11B-608.8 Shower Enclosures | Technical requirements for alternate roll-in type shower compartments applicable |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|---|
| 1115B.4.4.2 Thresholds. | 11B-608.7 Thresholds | Technical requirements for thresholds |
| 1115B.4.4.3 Orientation. | 11B-213.3.6 Bathing Facilities | Scoping requirement for orientation |
| 1115B.4.4.4 Water controls. | 11B-608.5 Controls | Technical requirements for controls |
| 1. Controls in a . . . roll-in shower . . . | 11B-608.5.2 Standard Roll-In Type Shower Compartments | Technical requirements for controls in standard roll-in type shower compartments |
| 2. Controls in an . . . alternate roll-in shower . . . | 11B-608.5.3 Alternate Roll-In Type Shower Compartments | Technical requirements for controls in alternate roll-in type shower compartments |
| 3. Controls in an . . . alternate roll-in shower . . . with optional enclosure . . . | 11B-608.5.3 Alternate Roll-In Type Shower Compartments | Technical requirements for controls in alternate roll-in type shower compartments applicable |
| 1115B.4.4.5 Hand-held sprayer unit. | 11B-608.6 Shower Spray Unit and Water | |
| 1. The hand-held sprayer unit . . . | 11B-608.5.2 Standard Roll-In Type Shower Compartments | Technical requirements for shower sprays in standard roll-in type shower compartments |
| 2. The hand-held sprayer unit . . . in an . . . alternate roll-in shower . . . | 11B-608.5.3 Alternate Roll-In Type Shower Compartments | Technical requirements for shower sprays in alternate roll-in type shower compartments |
| 3. The hand-held sprayer unit . . . in an . . . alternate roll-in shower . . . with optional enclosure . . . | 11B-608.5.3 Alternate Roll-In Type Shower Compartments | Technical requirements for shower sprays in alternate roll-in type shower compartments applicable |
| 1115B.4.4.6 Sprayer unit alternative. | 11B-608.6 Exception | Exception permitted in areas subject to excessive vandalism only |
| 1115B.4.4.7 Floor slope. | 11B-608.9 Shower Floor or Ground Surface | Technical requirements for shower floor surface |
| 1115B.4.4.8 Shower accessories. | 11B-608.1 General | General scoping for showers |
| 1. A folding seat . . . | <ul style="list-style-type: none"> • 11B-608.4 Seats • 11B-610.3 Shower Compartment Seats | Technical requirements for seats |
| 2. Grab bars located on walls . . . | 11B-608.3 Grab Bars | Technical requirements for grab bars |
| 1115B.4.4.9 Soap dish. | 11B-608.10 Soap Dish | Technical requirements for soap dishes |
| 1115B.4.4.10 Enclosures. | 11B-608.8 Shower Enclosures | Technical requirements of enclosures |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 1115B.4.5 Accessible bathtubs. | 11B-213.3.6 Bathing Facilities | General scoping for bathtubs |
| 1. Floor space. | 11B-607.2 Clearance | Technical requirements for clearances at bathtubs |
| 2. Seat. | <ul style="list-style-type: none"> • 11B-607.3 Seat • 11B-610.2 Bathtub Seats | Technical requirements for seats |
| 3. Grab bars. | 11B-607.4 Grab Bars | Technical requirements for grab bars |
| 4. Controls. | 11B-607.5 Controls | Technical requirements for controls |
| 5. Shower unit. | 11B-607.6 Shower Spray Unit and Water | Technical requirements for shower spray units. |
| 6. Bathtub enclosures. | 11B-607.7 Bathtub Enclosures | Technical requirements for enclosures |
| 1115B.5 Passageways. | <ul style="list-style-type: none"> • 11B-603.2.3 Door Swing • 11B-604.8.1.2 Doors | Technical requirements for doors and door swings |
| 1115B.6 Identification symbols. | <ul style="list-style-type: none"> • 11B-216.8 Toilet Rooms and Bathing Rooms • 11B-703.7.2.6 Toilet and Bathing Facilities Geometric Symbols | Scoping and technical requirements for geometric identification symbols at toilet and bathing rooms |
| 1115B.6.1 Men's sanitary facilities . . . | 11B-703.7.2.6.1 Men's Toilet and Bathing Facilities | Technical requirements for geometric identification symbols |
| 1115B.6.2 Woman's sanitary facilities . . . | 11B-703.7.2.6.2 Women's Toilet and Bathing Facilities | Technical requirements for geometric identification symbols |
| 1115B.6.3 Unisex sanitary facilities . . . | 11B-703.7.2.6.3 Unisex Toilet and Bathing Facilities | Technical requirements for geometric identification symbols |
| 1115B.7 Grab bars, tub and shower seats. | <ul style="list-style-type: none"> • 11B-609.1 General • 11B-610.1 General | General scoping for grab bars & seats |
| 1115B.7.1 Diameter or width. | <ul style="list-style-type: none"> • 11B-609.2 Cross Section • 11B-609.3 Spacing | Technical requirements for grab bar size and mounting distance from wall |
| 1115B.7.2 Structural strength. | <ul style="list-style-type: none"> • 11B-609.8 Structural Strength • 11B-610.4 Structural Strength | Technical requirements for the structural strength of grab bars, seats, fasteners, mounting devices or supporting structures |
| 1. Bending stress . . . | <ul style="list-style-type: none"> • 11B-609.8 Structural Strength • 11B-610.4 Structural Strength | Technical requirements for the structural strength of grab bars, seats, fasteners, mounting devices or supporting structures |
| 2. Shear stress . . . | <ul style="list-style-type: none"> • 11B-609.8 Structural Strength • 11B-610.4 Structural Strength | Technical requirements for the structural strength of grab bars, seats, fasteners, mounting devices or supporting structures |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|--|--|
| 3. Shear force induced . . . | <ul style="list-style-type: none"> • 11B-609.8 Structural Strength • 11B-610.4 Structural Strength | Technical requirements for the structural strength of grab bars, seats, fasteners, mounting devices or supporting structures |
| 4. Tensile force induced . . . | <ul style="list-style-type: none"> • 11B-609.8 Structural Strength • 11B-610.4 Structural Strength | Technical requirements for the structural strength of grab bars, seats, fasteners, mounting devices or supporting structures |
| 5. Grab bars shall not rotate within their fittings. | <ul style="list-style-type: none"> • 11B-609.8 Structural Strength • 11B-610.4 Structural Strength | Technical requirements for the structural strength of grab bars, seats, fasteners, mounting devices or supporting structures |
| 1115B.7.3 Surface. | 11B-609.5 Surface Hazards | Technical requirements for the surface of grab bars |
| 1115B.8 Accessories. | 11B-603.5 Accessories | Technical requirements for accessories |
| 1115B.8.1 Mirrors. | 11B-213.3.5 Mirrors | Scoping for mirrors in toilet and bathing facilities |
| 1115B.8.1.1. All mirrors located above accessible lavatories . . . | 11B-603.3 Mirrors | Technical requirements for mirrors |
| 1115B.8.1.2. When mirrors are provided other than above lavatories . . . | 11B-603.3 Mirrors | Technical requirements for mirrors |
| 1115B.8.1.3 | 11B-222.3 Mirrors | General scoping for mirrors in fitting and dressing rooms |
| 1115B.8.2 Medicine cabinets. | <ul style="list-style-type: none"> • 11B-225.2 Storage • 11B-603.4 Coat Hooks, Shelves and Medicine Cabinets | General scoping and technical requirement for coat hooks, shelves and medicine cabinets |
| 1115B.8.3 Towel, sanitary napkins, waste receptacles, dispensers and controls. | 11B-603.5 Accessories | Technical requirements for accessories |
| 1115B.8.4 Toilet tissue dispensers. | 11B-604.7 Dispensers | Technical requirements for toilet paper dispensers |
| 1115B.8.5 Lockers. | <ul style="list-style-type: none"> • 11B-225.2.1 Lockers • 11B-811 Storage | General scoping and technical requirements for lockers |

Section 1116B Elevators and Platform (Wheelchair) Lifts

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|---|
| 1116B.1 Elevators. | <ul style="list-style-type: none"> • 11B-206.6 Elevators • 11B-407.1 General • 11B-407.1.1 Combined Passenger and Freight Elevators | <p>Chapter 35 Referenced Standards ASME A17.1 Scoping for Elevators</p> <p>Technical requirements for combined passenger and freight elevators.</p> |
| 1116B.1.1 General. | N/A | Title only in 2010 CBC. |
| Exception 1. In existing buildings . . . | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2. In existing buildings . . . the minimum car plan dimension . . . | 11B-407.4.1 Car Dimensions. Exception. | In existing buildings, where existing shaft configuration or technical infeasibility prohibits strict compliance with 11B-407.4.1, existing elevator car configurations that provide a clear floor area of 18 square feet (1.67 m ²) minimum and also provide an inside clear depth 54 inches (1372 mm) minimum and a clear width 48 inches (1219 mm) minimum shall be permitted. |
| Exception 3. In existing buildings equivalent facilitation . . . | 11B-103 Equivalent Facilitation | General provision for equivalent facilitation is available; no need for specific exception. |
| Exception 4. These provisions shall not apply . . . | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1116B.1.2 Operation and leveling. | <ul style="list-style-type: none"> • 11B-407.1 General. • 11B-407.4.3 Platform to Hoistway Clearance. • 11B-407.4.4 Leveling. | Technical requirements for automatic operation, clearance and leveling. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 1116B.1.3 Door operation. | <ul style="list-style-type: none"> • 11B-407.3.1 Type. • 11B-407.3.2 Operation. | Technical requirements for door operation |
| 1116B.1.4 Door size. | 11B-407.4.1 Elevator Car Dimensions | Technical requirements for elevator car and door dimensions |
| 1116B.1.5 Door protective and reopening device | <ul style="list-style-type: none"> • 11B-407.3.3 Reopening Device • 11B-407.3.3.1 Height • 11B-407.3.3.2 Contact • 11B-407.3.3.3 Duration | Technical requirements for reopening device. |
| 1116B.1.6 Hall call. | 11B-407.3.4 Door and Signal Timing | Technical requirements for door and signal timing. |
| 1116B.1.7 Car | 11B-407.3.5 Door Delay | Technical requirement for door delay. |
| 1116B.1.8 Car inside. | <ul style="list-style-type: none"> • 11B-407.4.1 Car Dimensions. • 11B-407.4.2 Floor Surfaces. • 11B-407.4.6.1 Location • 11B-407.4.6.4 Emergency Controls • 11B-407.4.7.1.4 Visible Indicators • 11B-407.4.9 Emergency Communications • 11B-408.4.6 Location • 11B-409.4.6.2 Location | <p>Technical requirements for elevator car dimensions.</p> <p>Technical requirements for floor surfaces.</p> <p>Technical requirements for reach range</p> <p>Technical requirements for emergency controls</p> <p>Technical requirements for visible indicators.</p> <p>Technical requirements for emergency communications</p> <p>Technical requirements for location of control panels.</p> |
| 1116B.1.9 Car controls. | <ul style="list-style-type: none"> • 11B-407.4.6.2 Buttons • 11B-407.4.6.2.1 Size and Shape • 11B-407.4.6.2.3 Illumination • 11B-407.4.6.2.4 Operation • 11B-407.4.7.1.1 Type • 11B-407.4.7.1.2 Location • 11B-407.4.7.1.3 Symbols • 11B-407.4.8.1 Visible Indicators • 11B-407.4.8.2 Audible Indicators | Technical requirements for control buttons. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--------------------------------------|---|--|
| 1116B.1.10 Hall call buttons. | <ul style="list-style-type: none"> • 11B-407.2.1.1 Height • 11B-407.2.1.2 Size and Shape • 11B-407.2.1.3 Clear Floor or Ground Space • 11B-407.2.1.4 Location • 11B-407.4.8.2 Audible Indicators | Technical requirements for hall call buttons |
| 1116B.1.11 Handrails. | 11B-407.4.10 Support Rail | Technical requirements for support rail. |
| 1116B.1.12 Minimum illumination. | 11B-407.4.5 Illumination | Technical requirements for illumination at car, threshold and landing. |
| 1116B.1.13 Hall lantern. | <ul style="list-style-type: none"> • 11B-407.2.2.1 Visible and Audible Signals • 11B-407.2.2.2 Visible Signals • 11B-407.2.2.3 Audible Signals | Technical requirements for visible and audible signals. |
| 1116B.1.14 Doorjamb marking. | 11B-407.2.3.1 Floor Designation | Technical requirements for door jamb markings |
| 1116B.1.15 Location. | <ul style="list-style-type: none"> • 11B-402.2 Components • 11B-108 Maintenance of Accessible Features | Scoping for elevators |
| 1116B.2 Platform (wheelchair) lifts. | 11B-206.7 Platforms Lifts | Scoping for platform lifts |
| 1. | 11B-206.7.1 Performance Areas and Speakers' Platforms | Scoping for platform lifts |
| 2. | 11B-206.7.2 Wheelchair Spaces | Scoping for platform lifts |
| 3. | 11B-206.7.3 Incidental Spaces | Scoping for platform lifts |
| 4. | 11B-206.7.5 Existing Site Constraints | Scoping for platform lifts |
| Exception | 11B-206.7 Platform Lifts | Scoping for platform lifts. |
| 1116B.2.1 General. | 11B-410.1 General | Technical requirements for compliance with ASME A18.1 |
| 1116B.2.2 Unassisted entry. | 11B-410.1 General | Technical requirements for unassisted entry |
| 1116B.2.3 Landing size. | 11B-410.7 Landing Size | Technical requirements for landing size |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 1116B.2.4 Relationship to the path of travel. | 11B-402.2 Components | Location on accessible route |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1116B.2.5 When provided as a means of egress. | 11B-207.1 General | Scoping for platform lifts as a means of egress. |
| 1116B.2.5.1 Standby power. | 11B-207.2 Platforms Lifts | Scoping for standby power at platform lifts. |
| 1116B.2.5.2 | 11B-206.7.2 Wheelchair Spaces | Scoping for platform lifts, used to comply with line-of-sight and dispersion requirements. |
| 1116B.2.6 Doors and gates. | 11B-410.6 Doors and Gates | Technical requirements for doors and gates at platform lifts. |
| Exception | 11B-410.6 Doors and Gates, Exception | Technical requirements for doors and gates at platform lifts. |
| 1116B.2.7 Restriction sign. | 11B-410.8 Restriction Sign | Technical requirements for restriction sign. |

Section 1117B Other Building Components

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|--|--|
| 1117B.1 Accessible drinking fountains. | 11B-211.1 General | General scoping for drinking fountains. |
| 1. General. | <ul style="list-style-type: none"> • 11B-211.2 Minimum Number • 11B-211.3 More Than Minimum Number | General scoping for drinking fountains. |
| 2. Clearances. | <ul style="list-style-type: none"> • 11B-306 Knee and Toe Clearance • 11B-602.2 Clear Floor Space • 11B-602.8 Depth | Technical requirements for clear floor space, knee and toe clearance, and depth. |
| 3. Alcoves. | 11B-602.9 Pedestrian Protection | Technical requirements for pedestrian protection – alcoves or wing walls. |
| 4. | <ul style="list-style-type: none"> • 11B-602.4 Spout Height • 11B-602.5 Spout Location | Technical requirements for spout location and height. |
| 5. | 11B-602.6 Water Flow | Technical requirement for water flow. |
| 1117B.2 Telephones. | 11B-217.1 General | General scoping for public telephones |
| 1117B.2.1 General. | 11B-217.2 Wheelchair Accessible Telephones | General scoping for wheelchair accessible telephones |
| 1117B.2.2 Clear floor or ground space. | 11B-704.2.1 Clear Floor or Ground Space | Technical requirements for clear floor or ground space |
| 1117B.2.3 Size and approach. | <ul style="list-style-type: none"> • 11B-704.2.1.1 Parallel Approach • 11B-704.2.1.2 Forward Approach | Technical requirements for parallel or forward approach |
| 1117B.2.4 Relationship of maneuvering clearances to wheelchair spaces. | <ul style="list-style-type: none"> • 11B-704.2.1 Clear Floor or Ground Space • 11B-305.6 Approach | Technical requirements for clear floor space and approach |
| 1117B.2.5 Floor surfaces of wheelchair spaces. | <ul style="list-style-type: none"> • 11B-704.2.1 Clear Floor or Ground Space • 11B-302.1 General | Technical requirements for floor surfaces |
| 1117B.2.6 Mounting height. | <ul style="list-style-type: none"> • 11B-704.2.2. Operable Parts • 11B-309 Operable Parts | Technical requirements for mounting height of operable parts |
| 1117B.2.7 Enclosures. | 11B-704.2.1 Clear Floor or Ground Space | Technical requirements for clear floor space at an enclosure |
| 1. Side reach possible. | 11B-704.2.1.1 Parallel Approach | Technical requirements for parallel approach at a telephone within an enclosure |
| 2. Full-height enclosures. | 11B-704.2.1.2 Forward Approach | Technical requirements for forward approach at a telephone within an enclosure |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 3. Forward reach required. | 11B-704.2.1.2 Forward Approach | Technical requirements for forward approach at a telephone within an enclosure |
| 4. Protruding telephone enclosures. | 11B-307 Protruding Objects | Technical requirements for protruding objects |
| 1117B.2.8 Telephone equipment for hearing impaired persons. | 11B-704.3 Volume Control Telephones | Technical requirements for public telephones required to have volume controls |
| 1117B.2.9 Text telephones. | 11B-217.4 TTYs | General scoping for TTYs |
| 1117B.2.9.1 Where required. | <ul style="list-style-type: none"> • 11B-217.4.1 Bank Requirement • 11B-217.4.2 Floor Requirement | General scoping for the number of TTYs required in specific locations |
| 1. | <ul style="list-style-type: none"> • 11B-217.4.1 Bank Requirement • 11B-217.4.2 Floor Requirement | General scoping for the number of TTYs required in specific locations |
| 2. | <ul style="list-style-type: none"> • 11B-217.4.3.1 Public Buildings • 11B-217.4.4 Exterior Site Requirements | General scoping for the number of TTYs required in specific locations |
| 3. | 11B-217.4.6 Hospitals | General scoping for the number of TTYs required in specific locations |
| 4. | <ul style="list-style-type: none"> • 11B-217.4.3.2 Private Buildings • 11B-217.4.4 Exterior Site Requirements | General scoping for the number of TTYs required in specific locations |
| 5. | <ul style="list-style-type: none"> • 11B-217.4.3.2 Private Buildings • 11B-217.4.4 Exterior Site Requirements | General scoping for the number of TTYs required in specific locations |
| 1117B.2.9.2 General. | 11B-704.4 TTYs | Technical requirements for TTYs |
| 1. | 11B-704.4 TTYs | Technical requirements for TTYs |
| 2. | <ul style="list-style-type: none"> • 11B-217.5 Shelves for Portable TTYs • 11B-704.5 TTY Shelf | Scoping for shelves for portable TTYs |
| 3. | 11B-103 Equivalent Facilitation | General provision for the use of products providing equivalent facilitation |
| 1117B.2.9.3 Signage. | 11B-219 TTYs | Scoping for signs required for TTYs |
| 1117B.2.10 Controls. | 11B-704.2.2 Operable Parts | Technical requirements for operable parts |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 1117B.2.11 Cord length. | 11B-704.2.4 Cord Length | Technical requirements for cord length |
| 1117B.2.12 Telephone books. | 11B-704.2.3 Telephone Directories | Technical requirements for telephone directories |
| 1117B.3 Kitchens. | <ul style="list-style-type: none"> • 11B-233 Residential Facilities • 11B-804 Kitchens & Kitchenettes | <p>Scoping for Residential Facilities</p> <p>Technical requirements for kitchens & kitchenettes</p> |
| 1117B.4 Swimming pools. | <ul style="list-style-type: none"> • 11B-242 Swimming Pools, Wading Pools, and Spas • 11B-1009 Swimming Pools, Wading Pools, and Spas | <p>Scoping for swimming pools, wading pools, and spas.</p> <p>Technical requirements for swimming pools, wading pools, and spas.</p> |
| 1117B.5 Signs and identification. | <ul style="list-style-type: none"> • 11B-703 Signs | Obsolete advisory reference to Section 4.30 of the 1991 Standards not carried forward |
| 1117B.5.1 General. | <ul style="list-style-type: none"> • 11B-216.1 General • 11B-703.1 General | General scoping and technical requirements for signs |
| 1. Identification signs. | <ul style="list-style-type: none"> • 11B-216.2 Designations • 11B-703.2 Raised Characters • 11B-703.3 Braille | Scoping and technical requirements for interior and exterior signs identifying permanent room and spaces |
| 2. Directional and informational signs. | <ul style="list-style-type: none"> • 11B-216.3 Directional and Informational Signs • 11B-703.5 Visual Characters | Scoping and technical requirements for signs that provide directions to or information about facilities |
| 3. Accessibility signs. | 11B-703.7 Symbols of Accessibility | Scoping and technical requirements for symbols of accessibility |
| 4. Plan review and inspection. | 11B-703.1.1 Plan Review and Inspection | Plan review and inspection requirements |
| 4.1. Plan review. | 11B-703.1.1.1 Plan Review | Plan review and inspection requirements |
| 4.2. Inspection. | 11B-703.1.1.2 Inspection | Plan review and inspection requirements |
| 4.3. Other signs and identification. | 11B-703.1.1 Plan Review and Inspection | Plan review and inspection requirements |
| 1117B.5.2 Finish and contrast. | <ul style="list-style-type: none"> • 11B-703.5.1 Finish and Contrast • 11B-703.6.2 Finish and Contrast • 11B-703.7.1 Finish and Contrast | Technical requirements for non-glare finish on visual signs, including pictograms and symbols of accessibility |
| 1117B.5.3 Proportions. | <ul style="list-style-type: none"> • 11B-703.2.4 Character Proportions • 11B-703.2.6 Stroke Thickness | Technical requirements for characters on tactile signs |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 1117B.5.4 Character height. | <ul style="list-style-type: none"> • 11B-703.5.4 Character proportions • 11B-703.5.5 Character Height | Technical requirements for characters on visual signs |
| 1117B.5.5 Raised characters and pictorial symbol signs. | <ul style="list-style-type: none"> • 11B-703.2 Raised Characters • 11B-703.6 Pictograms | Technical requirements for raised characters and pictograms |
| 1. Character type. | <ul style="list-style-type: none"> • 11B-703.2.1 Depth • 11B-703.2.2 Case • 11B-703.2.3 Style | Technical requirements for depth, case & style of raised characters |
| 2. Character size. | 11B-703.2.5 Character Height | Technical requirements for height of raised characters |
| 3. Pictorial symbol signs (pictograms). | <ul style="list-style-type: none"> • 11B-703.6.1 Pictogram Field • 11B-703.6.3 Text Descriptors | Technical requirements for pictograms |
| 4. Character placement. | <ul style="list-style-type: none"> • 11B-703.2.9 Format • 11B-703.3.2 Position | Technical requirements for horizontal format and Braille position |
| 1117B.5.6 Braille. | <ul style="list-style-type: none"> • 11B-703.3 Braille • 11B-703.3.1 Dimensions and Capitalization | Technical requirements for Braille |
| 1117B.5.7 Mounting location and height. | <ul style="list-style-type: none"> • 11B-703.4.1 Height Above Finish Floor or Ground • 11B-703.4.2 Location | Technical requirements for mounting location and height |
| 1117B.5.8 Symbols of accessibility. | 11B-703.7.2 Symbols | Technical requirements for symbols of accessibility |
| 1117B.5.8.1 International Symbol of Accessibility. | 11B-703.7.2.1 International Symbol of Accessibility | Technical requirements for International Symbol of Accessibility |
| Exception | N/A | |
| 1117B.5.8.1.1 Color of symbol. | 11B-703.7.2.1 International Symbol of Accessibility | Technical requirements for International Symbol of Accessibility |
| Exception | 11B-703.7.2.1 Exception | Technical requirements for International Symbol of Accessibility |
| 1117B.5.8.1.2 Entrance signs. | 11B-216.6 Entrances | Scoping for sign requirements at entrance doors |
| Exception 1 | 11B-216.6 Entrances, Exception 1 | Scoping for sign requirements at entrance doors |
| Exception 2 | 11B-216.6 Entrances, Exception 2 | Scoping for sign requirements at entrance doors |
| 1117B.5.8.1.3 Information posted. | 11B-216.7 Elevators 11B-216.8 Toilet Rooms and Bathing Rooms | Scoping for signs providing information about specific accessible elements |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|---|
| 1117B.5.8.2 International TTY symbol. | <ul style="list-style-type: none"> • 11B-216.9 TTYs • 11B-703.7.2.2 International Symbol of TTY | Scoping and technical requirements for International Symbol of TTY |
| 1117B.5.8.3 Volume control telephones. | 11B-703.7.2.3 Volume Control Telephones | Scoping and technical requirements for volume control telephones |
| 1117B.5.8.4 Assistive listening systems. | <ul style="list-style-type: none"> • 11B-216.10 Assistive Listening Systems • 11B-703.7.2.4 Assistive Listening Systems | Scoping and technical requirements for assistive listening systems |
| 1117B.5.9 Traffic-control devices. | 11B-703.7.2.7 Pedestrian Traffic-Control Buttons | Scoping and technical requirements for pedestrian traffic-control buttons |
| 1117B.5.10 Signs for text telephones. | N/A | Reference to "TDD" designation not carried forward. |
| 1117B.5.11 Cleaner air symbol. | <ul style="list-style-type: none"> • 11B-216.13.1 Cleaner Air Symbol • 11B-703.7.2.5 Cleaner Air Symbol | Scoping and technical requirements for cleaner air symbol |
| 1117B.5.11.1 Color and size of symbol. | 11B-703.7.2.5 Cleaner Air Symbol | Technical requirements for cleaner air symbol |
| 1117B.5.11.2 Conditions of use. | 11B-216.13.1 Use of Cleaner Air Symbol | Scoping for use of cleaner air symbol |
| 1117B.5.11.3 Removal of symbol. | 11B-216.13.2 Removal of Cleaner Air Symbol | Scoping for removal of cleaner air symbol |
| 1117B.6 Controls and operating mechanisms. | 11B-205 Operable Parts | General scoping for operable parts |
| 1. General. | <ul style="list-style-type: none"> • 11B-205.1 General • 11B-309.1 General | General scoping for operable parts |
| 2. Clear floor space. | 11B-309.2 Clear Floor Space | Technical requirements for clear floor space |
| 3. Height. | 11B-309.3 Height | Technical requirements for height |
| Exception | 11B-205.1 General, Exceptions | General scoping for operable parts |
| 4. Operation. | 11B-309.4 Operation | Technical requirement for operation |
| 5. Installation heights of electrical switches and receptacle outlets. | <ul style="list-style-type: none"> • 11B-308.1.1 Electrical Switches • 11B-308.1.2 Electrical Receptacle Outlets | Technical requirements for electrical switches and receptacle outlets |
| 5.1. Electrical switches. | 11B-308.1.1 Electrical Switches | Technical requirements for electrical switches |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 5.2. Electrical receptacle outlets | 11B-308.1.2 Electrical Receptacle Outlets | Technical requirements for electrical receptacle outlets |
| Exception 1 | 11B-205.1 General, Exceptions | General scoping for operable parts |
| Exception 2 | 11B-205.1 General, Exceptions | General scoping for operable parts |
| Exception 3 | 11B-205.1 General, Exceptions | General scoping for operable parts |
| Exception 4 | 11B-205.1 General, Exceptions | General scoping for operable parts |
| 1117B.7 Automated teller machines and point of sale machines. | 11B-220 Automatic Teller Machines, Fare Machines and Point-of-Sale Devices | General scoping for automatic teller machines |
| 1117B.7.1 General. | 11B-220.1 Automatic Teller Machines and Fare Machines | General scoping for automatic teller machines |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 3 | 11B-308.3.1, Exception 2 | Exception for operable parts of fuel dispensers |
| 1117B.7.1.1 | 11B-220.1 Automatic Teller Machines and Fare Machines | Scoping for automatic teller machines |
| 1117B.7.1.1.1 One ATM. | 11B-220.1.1 One Automatic Teller Machine or Fare Machine | Scoping for automatic teller machines |
| 1117B.7.1.1.2 Two ATMs | 11B-220.1.2 Two Automatic Teller Machines or Fare Machines | Scoping for automatic teller machines |
| 1117B.7.1.1.3 Three or more ATMs | 11B-220.1.3 Three or More Automatic Teller Machines or Fare Machines | Scoping for automatic teller machines |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|--|---|
| 1117B.7.1.2 Where bins ... | 11B-220.1 Automatic Teller Machines and Fare Machines | Scoping for bins for envelopes, waste or other purposes |
| 1117B.7.1.3 (point-of-sale) | 11B-220.2 Point-of-Sale Devices | Scoping for point-of-sale devices |
| 1117B.7.2 Clear floor or ground space. | 11B-707.2 Clear Floor or Ground Space | Technical requirements for clear floor space |
| Exception | 11B-707.2 Exception | Exception for drive-up only machines |
| 1117B.7.3 Operable parts. | 11B-707.3 Operable Parts | Technical requirements for operable parts |
| Exception | 11B-707.3 Exception | Exception for drive-up only machines |
| 1117B.7.3.1 (clear key) | <ul style="list-style-type: none"> • 11B-707.5 Speech Output • 11B-707.6.1 Input Controls • 11B-707.6.3.2 Tactile Symbols | Technical requirements for operable parts discernible by sound or touch |
| 1117B.7.4 Privacy. | 11B-707.4 Privacy | Technical requirements for same degree of privacy of input and output |
| 1117B.7.5 Speech output. | 11B-707.5 Speech Output | Technical requirements for speech output |
| Exception 1 | 11B-707.5, Exception 1 | Technical requirements for speech output |
| Exception 2 | 11B-707.5, Exception 2 | Technical requirements for speech output |
| Exception 3 | 11B-707.5, Exception 3 | Technical requirements for speech output |
| 1117B.7.5.1 User control. | 11B-707.5.1 User Control | Technical requirement for user control of speech function |
| Exception | 11B-707.5.1, Exception | Technical requirement for user control of speech function |
| 1117B.7.5.2 Receipts. | 11B-707.5.2 Receipts | Technical requirements for receipts |
| Exception 1 | 11B-707.5.2, Exception 1 | Technical requirements for receipts |
| Exception 2 | 11B-707.5.2, Exception 2 | Technical requirements for receipts |
| Exception 3 | 11B-707.5.2, Exception 3 | Technical requirements for receipts |
| 1117B.7.6 Input. | 11B-707.6 Input | Technical requirements for input controls |
| 1117B.7.6.1 Input controls. | 11B-707.6.1 Input Controls | Technical requirements for input controls |
| 1117B.7.6.2 Numeric keys. | 11B-707.6.2 Numeric Keys | Technical requirements for input controls |
| 1117B.7.6.3 Function keys. | 11B-707.6.3 Function Keys | Technical requirements for input controls |
| 1117B.7.6.3.1 Contrast | 11B-707.6.3.1 Contrast | Technical requirements for input controls |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|---|
| Exception | 11B-707.6.3.1, Exception | Technical requirements for input controls |
| 1117B.7.6.3.2 Tactile symbols. | 11B-707.6.3.2 Tactile Symbols | Technical requirements for input controls |
| 1117B.7.7 Display screen. | 11B-707.7 Display Screen | Technical requirements for display screens |
| Exception | 11B-707.7, Exception | Technical requirements for display screens |
| 1117B.7.7.1 Visibility. | 11B-707.7.1 Visibility | Technical requirements for display screens |
| 1117B.7.7.1.1 Vertically mounted display screen. | 11B-707.7.1.1 Vertically Mounted Display Screen | Technical requirements for display screens |
| 1117B.7.7.1.2 Angle-mounted display screen. | 11B-707.7.1.2 Angle Mounted Display Screen | Technical requirements for display screens |
| 1117B.7.7.1.3 Horizontally mounted display screen. | 11B-707.7.1.3 Horizontally Mounted Display Screen | Technical requirements for display screens |
| 1117B.7.7.2 Characters. | 11B-707.7.2 Characters | Technical requirements for characters displayed on the screen |
| 1117B.7.8 Braille instructions. | 11B-707.8 Braille Instructions | Technical requirements for Braille instructions |
| 1117B.7.9 Point-of-sale devices | <ul style="list-style-type: none"> • 11B-707.9 Point-of-Sale Devices • 11B-707.9.1 General | Technical requirements for point-of-sale devices |
| 1117B.7.9.1 | 11B-707.9.1.1 Tactilely Discernible Numerical Keypad | Technical requirements for point-of-sale devices |
| 1117B.7.9.2 | 11B-707.9.1.2 Other Technology | Technical requirements for point-of-sale devices |
| 1117B.8 Fitting and dressing rooms. | <ul style="list-style-type: none"> • 11B-222 Dressing, Fitting and Locker Rooms • 11B-803 Dressing, Fitting and Locker Rooms • 11B-903 Benches | Scoping and technical requirements for dressing and fitting rooms, including clear space, benches, coat hooks and mirrors |
| 1117B.9 Accessible sinks. | <ul style="list-style-type: none"> • 11B-212.3 Sinks | General scoping for sinks |
| 1. | 11B-606.2 Clear Floor Space | Technical requirements for clear floor space |
| 2. | <ul style="list-style-type: none"> • 11B-606.3 Height • 11B-606.2 Clear Floor Space • 11B-606.5 Exposed Pipes and Surfaces • 11B-606.7 Sink Depth | Technical requirements for height, knee & toe clearance, depth and exposed pipes |
| 3. | 11B-606.4 Faucets | Technical requirements for control |

Section 1118B Space Allowance and Reach Ranges

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|--|---|
| 1118B.1 Wheelchair passage width. | <ul style="list-style-type: none"> • 11B-403.5.1 Clear Width • 11B-403.5.1, Exception 1 • 11B-403.5.2 Clear Width at Turn | Technical requirements for clear width, clear width at a point and clear width at turns around obstructions |
| 1118B.2 Width for wheelchair passing. | 11B-403.5.3 Passing Spaces | Technical requirements for passing spaces |
| 1118B.3 Wheelchair turning space. | 11B-304.3 Size | Technical requirements for turning space – circular or T-shaped |
| 1118B.4 Clear floor or ground space for wheelchairs. | 11B-305 Clear Floor or Ground Space | Technical requirements for clear floor or ground space |
| 1. Size and approach. | <ul style="list-style-type: none"> • 11B-305.3 Size • 11B-305.4 Knee and Toe Clearance • 11B-305.5 Position | Technical requirements for clear floor or ground space – size, knee & toe space, parallel or forward approach |
| 2. Relationship of maneuvering clearances to wheelchair spaces. | <ul style="list-style-type: none"> • 11B-305.6 Approach • 11B-305.7 Maneuvering Clearance | Technical requirements for clear floor or ground space – accessible route and maneuvering clearances at alcoves |
| 3. Surfaces for wheelchair spaces. | 11B-305.2 Floor or Ground Surfaces | Technical requirements for clear floor or ground space – floor or ground surface |
| 1118B.5 Forward reach. | 11B-308.2 Forward Reach | Technical requirements for forward reach |
| 1118B.5.1 Unobstructed. | 11B-308.2.1 Unobstructed | Technical requirements for forward reach |
| 1118B.5.2 Obstructed high reach. | 11B-308.2.2 Obstructed High Reach | Technical requirements for forward reach |
| 1118B.6 Side reach. | 11B-308.3 Side Reach | Technical requirements for side reach |
| 1118B.6.1 Unobstructed. | 11B-308.3.1 Unobstructed | Technical requirements for side reach |
| Exception | 11B-308.3.1, Exception 1 | Technical requirements for side reach |
| 1118B.6.2 Obstructed High reach. | 11B-308.3.2 Obstructed High Reach | Technical requirements for side reach |
| Exception | 11B-308.3.2, Exception 1 | Technical requirements for side reach |

Section 1119B Special Standards of Accessibility for Buildings with Historical Significance

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|----------------------|---|---|
| See Section 1135B | 11B-202.5 Alterations to Qualified Historic Buildings and Facilities. | Current reference to State Historic Building Code accessibility provisions is maintained in 2013 CBC. |

Section 1120B Floor and Levels

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|-----------------------------------|---|--|
| 1120B.1 Floors within each story. | <ul style="list-style-type: none"> • 11B-206 Accessible Routes • 11B-302 Floor or Ground Surfaces | |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 3 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 4 | N/A | |
| 1120B.2 Floor surface. | 11B-302.1 General | Technical requirement for slip resistant floor surfaces |

Section 1121B Transportation Facilities

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 1121B.1 General. | <ul style="list-style-type: none"> • 11B-810 Transportation facilities • 11B-206 Accessible Route • 11B-206.2.3 Exception 2.2 Elevator requirements | <p>Technical requirements for transportation facilities.</p> <p>Scoping for accessible route.</p> <p>Scoping for elevators.</p> |
| 1121B.2 Bus stops and terminals. | 11B-209.2.2 Bus Loading Zones | Scoping for bus loading zones. |
| 1121B.2.1 New construction. | <ul style="list-style-type: none"> • 11B-810.2.1 Surface • 11B-810.2.2 Dimensions • 11B-810.2.3 Connections • 11B-810.2.4 Slope • 11B-810.3 Bus Shelters • 11B-810.4 Bus Signs • 11B-705.1.2.4 Bus Stops | <p>Technical requirements for bus boarding, alighting areas and bus shelters.</p> <p>Technical requirements for detectable warnings and square curbs.</p> |
| 1121B.2.2 Bus stop siting and alterations. | <ul style="list-style-type: none"> • 11B-209.2.2 Bus Loading Zones • 11B-209.2.3 On-Street Bus Stops • 11B-218.4 Bus Shelters | Scoping for bus loading zones. |
| 1. | 11B-402.2 Accessible Route Components | Technical requirements for components of accessible routes. |
| 2. | 11B-810.4 Bus Signs | Technical requirements for bus signs. |
| 1121B.3 Fixed facilities and stations. | <ul style="list-style-type: none"> • 11B-218 Transportation Facilities • 11B-810 Transportation Facilities | <p>Scoping for transportation facilities</p> <p>Technical requirements for transportation facilities</p> |
| 1121B.3.1 New construction. | 11B-201.1 Scope | Scoping for new construction and alterations for facilities. |
| 1. | <ul style="list-style-type: none"> • 11B-206.3 Location • 11B-216.6 Entrance | <p>Scoping for location of accessible route to coincide with general circulation path.</p> <p>Scoping for signage located where accessible route diverges from regular circulation path.</p> |
| 2. | <ul style="list-style-type: none"> • 11B-206.4.1 General • 11B-206.4.4 Transportation Facilities | Scoping requires all entrances and exterior ground-floor exit doors to buildings and facilities to be accessible. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|--|--|
| 3. | <ul style="list-style-type: none"> • 11B-206.2.1 Site Arrival Points • 11B-206.4.2.2 Direct Connections | Scoping for accessible route provided within the site to facilities and transportation stops. |
| 4. | <ul style="list-style-type: none"> • 11B-216.6 Entrances • 11B-810.6.1 Entrances | Scoping for signage located at entrances. Technical requirements for signage at rail stations. |
| 5. | <ul style="list-style-type: none"> • 11B-810.6 Entrances • 11B-810.6.3 Station Names | Technical requirements for signage at rail stations. |
| 6. | 11B-810.6.2 Routes and Destinations | Technical requirements for signage at rail stations. |
| 7. | <ul style="list-style-type: none"> • 11B-220.1 General Automatic Teller and Fare Machines and Point-of-Sale Devices • 11B-707.2 Clear Floor and Ground Space • 11B-404 Doors, Doorways, and Gates | <p>Scoping for fare machines.</p> <p>Technical requirements for fare machines.</p> <p>Technical requirements for doors and gates.</p> |
| 8. | 11B-810.5.2 Detectable Warnings | Technical requirements for detectable warnings at platform edges. |
| (a) Detectable warnings at transit boarding platforms. | <ul style="list-style-type: none"> • 11B-705.1.2.1 Platform Edges • 11B-705.1 Detectable Warnings • 11B-705.3 Product Approval • 11B-705.1.1.3 Contrast | <p>Technical requirements for detectable warnings at platforms edges.</p> <p>Technical requirements for detectable warnings.</p> <p>Technical requirements for product approval.</p> <p>Technical requirements for contrast formula.</p> |
| (b) Detectable directional texture at boarding platforms. | <ul style="list-style-type: none"> • 11B-705.2 Detectable Directional Texture • 11B-705.3 Product Approval | <p>Technical requirements for detectable directional texture.</p> <p>Technical requirements for product approval.</p> |
| 9. | 11B-810.5.3 Platform and Vehicle Floor Coordination | Technical requirements for platform and vehicle floor coordination. |
| Exception 1 | 11B-810.5.3 Platform and Vehicle Floor Coordination | Technical requirements for platform and vehicle floor coordination. Requirements further defined in 36 CFR Part 1192. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|----------------------|---|---|
| Exception 2 | 11B-810.5.3 Platform and Vehicle Floor Coordination | Technical requirements for platform and vehicle floor coordination. Requirements further defined in 36 CFR Part 1192. |
| 10. | 11B-810.1 Vehicle Boarding | Technical requirements for vehicle boarding. |
| 11. | N/A | Not carried forward |
| 12. | 11B-217.4 TTYs | Technical requirements for TTYs |
| a. | 11B-217.4.1 Bank Requirement 11B-217.4.7 Transportation Facilities | Scoping for required number of TTYs |
| b. | 11B-217.4.3.1 Public Buildings | Scoping for required number of TTYs in public buildings |
| 13. | 11B-247.1.2.7 Track Crossings 11B-705.1.2.7 Track Crossings | Model code amended to provide scoping and technical requirements for detectable warnings at track crossings. |
| 14. | <ul style="list-style-type: none"> • 11B-218.5 Other Transportation Facilities • 11B-810.7 Public Address Systems | <p>Scoping requirement for public address systems and visual format.</p> <p>Technical requirement for public address systems and visual format.</p> |
| 15. | <ul style="list-style-type: none"> • 11B-218.5 Other Transportation Facilities • 11B-810.8 Clocks | <p>Scoping requirement for public address systems and visual format.</p> <p>Technical requirements for clocks.</p> |
| 16. | 11B-810.9 Escalators | Technical requirements for escalators. Additional requirements defined in ASME A17.1 |
| 17. | N/A | Not carried forward, security issue not access related. |
| Exception | N/A | Related to Item 17, not carried forward. |
| 18. | <ul style="list-style-type: none"> • 11B-904.4 Sales and Service Counters • 11B-904.4.1 Parallel Approach • 11B-904.4.2 Forward Approach | Technical requirements for sales and service counters. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|---|
| 19. | <ul style="list-style-type: none"> • 11B-810.1.3 Baggage Retrieval Systems • 11B-206.8 Security Barriers • 11B-404.2.10 Door and Gate Surfaces | <p>Technical requirements for baggage retrieval systems.</p> <p>Scoping for security barriers.</p> <p>Technical requirements for gates.</p> |
| 1121B.3.2 Existing facilities—alterations. | <ul style="list-style-type: none"> • 11B-202.3 Alterations • 11B-202.4 Path of Travel • 11B-218.2 New and Altered Fixed Guideway Systems. | Scoping for alterations in transportation facilities. |
| 1121B.4 Airports. | N/A | Title only in 2010 CBC. |
| 1121B.4.1 New construction. | <ul style="list-style-type: none"> • 11B-201.1 Scope • 11B-218.5 Other Transportation Facilities | Scoping for all areas of newly designed and constructed buildings and facilities. |
| 1. | 11B-206.3 Location | Scoping for location of accessible route to coincide with general circulation path. |
| 2. | 11B-216.6 Entrance | Scoping for signage located where accessible route diverges from regular circulation path. |
| 3. | <ul style="list-style-type: none"> • 11B-904.4 Sales and Service Counters • 11B-904.4.1 Parallel Approach • 11B-904.4.2 Forward Approach | Technical requirements for sales and service counters. |
| 4. | <ul style="list-style-type: none"> • 11B-217.4.1 Bank Requirement • 11B-217.4.7 Transportation Facilities | Scoping for required number of TTYs |
| 5. | <ul style="list-style-type: none"> • 11B-810.1.3 Baggage Retrieval Systems • 11B-206.8 Security Barriers • 11B-404.2.10 Door and Gate Surfaces | <p>Technical requirements for baggage retrieval systems.</p> <p>Scoping for security barriers.</p> <p>Technical requirements for gates.</p> |
| 6. | <ul style="list-style-type: none"> • 11B-218.5 Other Transportation Facilities • 11B-810.7 Public Address Systems | <p>Scoping requirement for public address systems and visual format.</p> <p>Technical requirement for public address systems and visual format.</p> |
| 7. | 11B-810.8 Clocks | Technical requirements for clocks. |

Section 1122B Fixed or Built-In Seating, Tables and Counters

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 1122B.1 Minimum number. | <ul style="list-style-type: none"> • 11B-206.2.4 Spaces and Elements • 11B-226.1 General | Scoping for fixed or built-in seating or tables |
| 1122B.2 Seating. | 11B-902.2 Clear Floor or Ground Space | Technical requirements for clear floor space |
| 1122B.3 Knee clearance. | <ul style="list-style-type: none"> • 11B-306.2.3, Exception 2 • 11B-306.3.3, Exception 3 • 11B-306.3.4, Exception 2 • 11B-902.2 Clear Floor or Ground Space | Technical requirements for knee and toe clearance |
| Exception | 11B-226.1, Exception 1 | Exception for knee and toe clearance at sales and service counters |
| 1122B.4 Height of work surfaces. | <ul style="list-style-type: none"> • 11B-226.1 General • 11B-902.3 Height | Scoping and technical requirements for height of work surfaces |
| 1122B.5 Sales and service counters, teller windows and information counters. | <ul style="list-style-type: none"> • 11B-227.3 Counters • 11B-904.4 Sales and Service counters | Scoping and technical requirements for sales and service counters |
| Exception | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |

Section 1123B Access to Employee Areas

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|------------------------|---|--|
| 1123B.1 General. | 11B-203.9 Employee Work Areas | General scoping for employee work areas |
| 1123B.2 Work stations. | <ul style="list-style-type: none"> • 11B-203.9 Employee Work Areas • 11B-206.2.8 Employee Work Areas | General scoping for employee work areas – including accessible route |
| Exception | <ul style="list-style-type: none"> • 11B-203.3 Raised Areas • 11B-203.4 Limited Access Spaces • 11B-203.5 Machinery Spaces | Exception to the requirements of accessibility |

Section 1124B Ground and Floor Surfaces

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---------------------------|---|---|
| 1124B.1 General. | <ul style="list-style-type: none">• 11B-302 Floor and Ground Surfaces• 11B-302.1 General | Technical requirements for floor and ground surfaces – slip resistance |
| 1124B.2 Changes in level. | 11B-303 Changes in Level | Technical requirements for floor and ground surfaces – changes in level |
| 1124B.3 Carpet. | 11B-302.2 Carpet | Technical requirements for floor and ground surfaces – carpet |
| 1124B.4 Gratings. | 11B-302.4 Openings | Technical requirements for floor and ground surfaces – openings or gratings |

Section 1125B Storage

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|----------------------------|---------------------------------------|------------------------------------|
| 1125B.1 General. | 11B-225.2 Storage | Scoping for storage |
| 1125B.2 Clear floor space. | 11B-811.2 Clear Floor or Ground Space | Technical requirements for storage |
| 1125B.3 Height. | 11B-811.3 Height | Technical requirements for storage |
| 1125B.4 Hardware. | 11B-811.4 Operable Parts | Technical requirements for storage |

Section 1126B Vending Machines and Other Equipment

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|--|---|
| 1126B Vending machines and other equipment | <ul style="list-style-type: none"><li data-bbox="570 268 927 384">• 11B-228 Depositories, Vending Machines, Change Machines, Mail Boxes and Fuel Dispensers<li data-bbox="570 426 878 457">• 11B-309 Operable Parts | Scoping for vending machines and other type of equipment Technical requirements for operable parts |

Section 1127B Exterior Routes of Travel

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|----------------------------------|---|--|
| 1127B.1 General. | <ul style="list-style-type: none"> • 11B-206.2.1 Site Arrival Points • 11B-206.2.2 Within a Site • 11B-206.3 Location • 11B-206.4 Entrances | Scoping for site and entrance accessibility |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1127B.2 Design and construction. | 11B-201.1 Scope | Scoping for construction of buildings and facilities |
| 1127B.3 Signs. | 11B-216.6 Entrances | Scoping for signs where accessible routes diverge from the regular circulation path |
| 1127B.4 Outside stairways. | N/A | |
| 1127B.5 Curb ramps. | <ul style="list-style-type: none"> • 11B-402.2 Components • 11B-406 Curb Ramps, Blended Transitions and Islands | Scoping and technical requirements for curb ramps |
| 1. General. | 11B-406.5.1 Location | Technical requirements for curb ramps – location |
| 2. Width of curb ramps. | 11B-406.5.2 Width | Technical requirements for curb ramps – width |
| 3. Slope of curb ramps. | <ul style="list-style-type: none"> • 11B-406.2.1 Slope • 11B-406.3.1 Slope • 11B-406.4.1 Slope | Technical requirements for curb ramps - slope |
| 4. Level landing. | <ul style="list-style-type: none"> • 11B-406.2.2 Sides of Curb Ramps • 11B-406.5.3 Landings | Technical requirements for curb ramps – landings and slope of curb ramp flares |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|-------------------------|--|--|
| 5. Finish. | N/A | Detectable warning satisfies the requirement for contrast. |
| 6. Border. | 11B-406.5.11 Grooved Border | Technical requirements for curb ramps – grooved border |
| 7. Detectable warnings. | <ul style="list-style-type: none"> • 11B-406.5.12 Detectable Warnings • 11B-705.1.2.2 Curb Ramps | Technical requirements for curb ramps – detectable warnings |
| 8. Obstructions. | 11B-406.5.1 Location | Technical requirements for curb ramps – obstruction by parked vehicles |
| 9. Diagonal curb ramps. | 11B-406.5.10 Diagonal Curb Ramps | Technical requirements for curb ramps – diagonal curb ramps |
| Notes: | N/A | Generally incorporated into 11B-406. |

Section 1128B Pedestrian Grade Separations (Overpasses and Underpasses)

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 1128B Pedestrian grade separations (overpasses and underpasses) | <ul style="list-style-type: none"> • 11B- 206.2.1 Site Arrival Points • 11B-206.2.2 Within a Site • 11B-206.4.3 Entrances from Tunnels or Elevated Walkways | Scoping for accessible routes |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |

Section 1129B Accessible Parking Required

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|---|
| 1129B.1 General. | <ul style="list-style-type: none"> • 11B-208.1 General. • 11B-208.3.1 General. • Table 11B-208.2 Parking Spaces | <p>Scoping for accessible parking</p> <p>Requires parking to be on the closest accessible route to the entrance, dispersed when there are multiple entrances and when parking doesn't serve a particular building to be on the shortest accessible route to the entrance of the parking facility.</p> <p>The number of accessible spaces required is shown in the table.</p> |
| 1129B.2 Medical care outpatient facilities. | <ul style="list-style-type: none"> • 11B-208.2.1 • 11B-208.2.2, see below | Current 2010 CBC provisions are included within the model code. |
| 1. Outpatient units and facilities. | 11B-208.2.1 Hospital Outpatient Facilities | Current 2010 CBC provisions are included within the model code, which expands the scope for a 10 percent parking ratio to include all outpatient facilities, not just those serving persons with mobility impairments. |
| 2. Units and facilities that specialize in treatment or services for persons with mobility impairments. | 11B-208.2.2 Rehabilitation Facilities and Outpatient Physical Therapy Facilities. | Current 2010 CBC provisions are included within the model code. |
| 1129B.3 Parking space size. | 11B-208.3.1 General. | Current redundant 2010 CBC reference eliminated. |
| 1. Dimensions. | <ul style="list-style-type: none"> • 11B-502.2 Vehicle Spaces • 11B-502.3 Access Aisle. • 11B-502.3.3 Marking. | <p>Model code is being amended to carry forward the current 2010 CBC minimum width of 108 inches and minimum length of 216 inches for standard accessible spaces.</p> <p>Current provisions allowing two accessible parking spaces to share an access aisle are included within the model code.</p> <p>Current 2010 CBC provisions for marking access aisles have been included by amendment.</p> |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|----------------------------------|--|---|
| 2. Van space(s). | <ul style="list-style-type: none"> • 11B-208.2.4 Van Parking Spaces. • 11B-502.2 Vehicle Spaces • 11B-208.3.1, Exception 1 • 11B-502.3.3 Marking. • 11B-502.3.4 Location. | <p>Current 2010 CBC van to standard parking space ratio of 1 to 8 has been superseded by more stringent model code requirement of 1 to 6.</p> <p>Model code is being amended to carry forward the current 2010 CBC minimum width of 144 inches and minimum length of 216 inches for van spaces with the option of a standard width accessible parking space with a 96 inch minimum width aisle.</p> <p>Current 2010 CBC provisions allowing van parking spaces to be grouped on one level within a multi-story parking facility are included within the model code.</p> <p>Current 2010 CBC provisions for marking access aisles have been included by amendment.</p> <p>Current 2010 CBC provisions requiring access aisle for van spaces to be on the passenger side have been included by amendment.</p> |
| 3. Arrangement of parking space. | 11B-502.2 Vehicle Spaces | Current 2010 CBC requirement that a person with a disability need not walk or wheel behind any vehicle other than their own is implemented by model code language requiring access aisles to adjoin an accessible route. |
| Exception 1. | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2. | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|--|---|
| 4. Slope of parking space and access aisle. | 11B-502.4 Floor or Ground Surfaces. | Model code language, with a non-substantive adjustment of the maximum slope to 1:48 from 1:50, carries forward the 2010 CBC requirements. |
| 5. Vertical clearance. | 11B-502.5 Vertical Clearance. | The required 98 inch overhead clearance for both standard and van spaces and at least one vehicular access route serving them is carried forward to the 2013 CBC by amendment. |
| 1129B.4. Identification of parking spaces for off-street parking facilities. | <ul style="list-style-type: none"> • 11B-502.6 Identification, including sub-sections • 11B-502.6.4.1 The outline of the International Symbol of Accessibility . . . • 11B-703.7.2.1 International Symbol of Accessibility. | <p>California statutory requirements for the marking, identification and signage of accessible off-street parking facilities are carried forward to the 2013 CBC by amendment.</p> <p>California statutory requirements for the surface marking of each accessible parking space are carried forward to the 2013 CBC by amendment. Current language referring to the depiction of a wheelchair and its occupant has been updated to a reference to the International Symbol of Accessibility.</p> |

Section 1130B Parking Structures

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|----------------------|---|--|
| 1130B.1 | 11B-502.5 Vertical Clearance. | The required 98 inch overhead clearance is carried forward to the 2013 CBC. |
| Exception 1. | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2. | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1130B.2 | 11B-206.4.2 Parking Structure Entrances | The requirement that each direct pedestrian entrance from a parking facility must be on an accessible route is maintained in the 2013 CBC. |

Section 1131B Passenger Drop-Off and Loading Zones

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|-------------------------------------|---|---|
| 1131B.1 Location. | <ul style="list-style-type: none"> • 11B-209 Passenger Loading Zones and Bus Stops • 11B-209.1 General. | Scoping for passenger drop-off and loading zones |
| 1131B.2 Passenger loading zones. | N/A | Title only in 2010 CBC |
| 1. General. | <ul style="list-style-type: none"> • 11B-209.2 Type. • 11B-503 Passenger Drop-Off and Loading Zones | Scoping and technical requirements for passenger drop-off and loading zones |
| 2. Vertical clearance. | 11B-503.5 Vertical Clearance. | Technical requirement to maintain 114 inch clearance |
| 1131B.3 Valet parking. | 11B-209.4 Valet Parking. | Scoping and technical requirements for valet parking |
| 1131B.4 Bus stop pads and shelters. | <ul style="list-style-type: none"> • 11B-209.2.2 Bus Loading Zones • 11B-209.2.3 On-Street Bus Stops. • 11B-810.2 Bus Boarding and Alighting Areas | Scoping and technical requirements for bus stop pads and shelters |

Section 1132B Outdoor Occupancies

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---------------------------------------|---|--|
| 1132B.1 General. | <ul style="list-style-type: none"> • 11B-201.1 Scope. • 11B-246 Parks and Recreational Areas. | All areas of newly designed and newly constructed buildings and facilities and altered portions of existing buildings and facilities shall comply with these requirements. Scoping for parks and recreational areas |
| 1132B.2 Parks and recreational areas. | 11B-246.1 General. | Scoping for parks and recreational areas |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | 11B-246.1 General, Exception | The existing exception to preclude material damage to the natural environment has been carried forward. |
| Exception 3 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1. Campsites. | 11B-246.2 Camping Facilities. | Current 2010 CBC provisions have been included by amendment. |
| 2. Beaches, picnic areas. | <ul style="list-style-type: none"> • 11B-246.1 General • 11B-246.3 Beaches. • 11B-246.4 Day Use Areas and Vista Points • 11B-246.5 Picnic Areas | Current 2010 CBC provisions have been included by amendment. Requirement for accessible picnic tables has been clarified at a level consistent with the ratios for dining areas. Current levels of access are maintained by the requirement for accessible routes to buildings and other functional areas |
| 3. Sanitary facilities. | 11B-213 Toilet Facilities and Bathing Facilities | Scoping for toilet and bathing facilities |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---------------------------------|--|---|
| 4. Boat docks. | <ul style="list-style-type: none"> • 11B-235 Recreational Boating Facilities • 11B-1003 Recreational Boating Facilities • 11B-237 Fishing Piers and Platforms • 11B-1005 Fishing Piers and Platforms | The model code's specific provisions provide enforceable requirements in lieu of the current 2010 CBC general statement of intent. |
| 5. Parking lots. | 11B-502.1 General. | Technical requirements for parking |
| 6. Trails and paths. | 11B-246.7 Trails and Paths. | Current 2010 CBC provisions have been included by amendment. |
| 7. Nature trails. | 11B-246.8 Nature Trails. | Current 2010 CBC provisions have been included by amendment. |
| 1132B.3 Highway rest areas. | 11B-201.1 Scope. | As a primary function area, the facilities at a highway rest stop will need to comply with the ADA and the 2013 CBC, which requires that "All areas of newly designed and newly constructed buildings and facilities and altered portions of existing buildings and facilities shall comply with these requirements." |
| 1132B.3.1 Permanent facilities. | 11B-201.1 Scope. | These limited specific references are provided for in the overall 2013 Chapter 11B; the current provisions are redundant. |

Section 1133B General Accessibility for Entrances, Exits and Paths of Travel

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 1133B.1 Building accessibility. | 11B-206.4 Entrances | General scoping for entrances |
| 1133B.1.1 Entrances. | 11B-206.4 Entrances | General scoping for entrances |
| 1133B.1.1.1 Entrances and exterior ground floor exit doors. | 11B-206.4 Entrances | General scoping for entrances |
| 1133B.1.1.1.1 | <ul style="list-style-type: none"> • 11B-206.2.1 Site Arrival Points • 11B-206.2.2 Within a Site • 11B-206.2.4 Spaces and Elements • 11B-206.4 Entrances • 11B-404.2.3 Clear Width | <p>Scoping and technical requirements for entrances – connection to public transportation stops, passenger loading zones, parking and all accessible spaces and elements within the building or facility.</p> <p>Technical requirements differ from ADAS by requiring <u>all</u> entrances and exterior ground floor exits to be accessible</p> |
| Exception 1 | 11B-206.4.1, Exception 1 | Exception for exterior ground floor exits serving smoke-proof enclosures, stairwells and exit doors servicing stairs only |
| Exception 2 | 11B-206.4.1, Exception 2 | Exception for exits in excess of those required by Chapter 10 and more than 24" above grade |
| Exception 3 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 4 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1133B.1.1.1.2 Temporary restrictions. | 11B-108 Maintenance of Accessible Features | Scoping for maintenance of accessible features. |
| 1133B.1.1.1.3 Recessed doormats. | <ul style="list-style-type: none"> • 11B-302.1 Floor or Ground Surfaces • 11B-302.2 Carpet | <p>Technical requirements for floor or ground surfaces.</p> <p>Technical requirement for carpet.</p> |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 1133B.1.1.1.4 Gates. | 11B-206.5 Doors, Doorways and Gates | General scoping for doors, doorways and gates |
| 1133B.1.1.1.5 Service entrances. | 11B-206.4.8 Service Entrances | Model code amended to require service entrance shall not be the sole accessible entrance unless it is the only entrance to a building or facility. |
| 1133B.2 Doors. | <ul style="list-style-type: none"> • 11B-206.5 Doors, Doorways and Gates • 11B-404.1 General | General scoping and technical requirements for doors, doorways and gates |
| 1133B.2.1 Type of lock or latch. | <ul style="list-style-type: none"> • Chapter 10, Section 1008.1.9 Door operations • 11B-404.2.7 Door and Gate Hardware | Technical requirements for door operations |
| 1133B.2.2 Width and height. | 11B-404.2.3 Clear Width | Technical requirements for door – width, height and clear width. Provides for consistency with 2010 ADAS and Chapter 10 CBC. |
| Exception | 11B-404.2.3 Clear Width Exception 3 | Model code amended for doors not requiring full user passage, such as at shallow closets – 20” minimum clear opening. |
| 1133B.2.3 Hinged doors. | 11B-404.2.3 Clear Width | Technical requirements for doors – openings measured with door open 90 degrees |
| 1133B.2.3.1 Pairs of doors. | <ul style="list-style-type: none"> • 11B-404.2.2 Double-Leaf Doors and Gates • 11B-404.2.3 Clear Width | Technical requirements for doors – pairs of doors |
| 1133B.2.3.2 Automatic and power-assisted doors. | 11B-404.3 Automatic and Power-Assisted Doors and Gates | Technical requirements for doors – automatic and power-assisted doors |
| Exception 1 | 11B-404.2.3, Exception 1 | Exception to the door clear width requirements in alterations |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 1133B.2.3.3 Revolving doors. | 11B-404.2.1 Revolving Doors, Gates and Turnstiles | Technical requirements for doors – revolving doors shall not be part of an accessible route |
| 1133B.2.3.4 Turnstiles, rails and pedestrian controls. | 11B-206.3 Location | Scoping for location of accessible route to coincide with or be located in the same area as general circulation paths. |
| Exception | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1133B.2.4 Floor level at doors. | 11B-404.2.4.4 Floor or Ground Surface | Technical requirements for doors - |
| 1133B.2.4.1 Thresholds. | 11B-404.2.5 Thresholds | Technical requirements for doors – thresholds |
| 1133B.2.4.2 Maneuvering clearances at doors. | <ul style="list-style-type: none"> • 11B-404.2.4 Maneuvering Clearances • 11B-404.2.4.4 Floor or Ground Surface | Technical requirements for doors – maneuvering clearances at swinging doors, doorways without doors, sliding doors and folding doors |
| Exception | <ul style="list-style-type: none"> • 11B-404.2.4 Maneuvering Clearances • 11B-404.2.4.4 Floor or Ground Surface | Technical requirements for doors – maneuvering clearances at swinging doors, doorways without doors, sliding doors and folding doors |
| 1133B.2.4.3 | <ul style="list-style-type: none"> • 11B-404.2.4 Maneuvering Clearances | Technical requirements for doors – maneuvering clearances at swinging doors, doorways without doors, sliding doors and folding doors |
| 1133B.2.4.4 | 11B-404.2.6 Doors in Series and Gates in Series | Technical requirements for doors – doors in series |
| 1133B.2.4.5 Recessed doors. | 11B-404.2.4.3 Recessed Doors and Gates | Technical requirements for doors – recessed doors |
| 1133B.2.5 Door opening force. | 11B-404.2.9 Door and Gate Opening Force | Technical requirements for doors – opening force |
| 1. | 11B-404.2.9, Item 3 | Technical requirements for doors – opening force for required fire doors |
| 2. | 11B-404.2.9, Item 1 & 2 | Technical requirements for doors – opening force for interior doors |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 3. | 11B-404.2.9, Item 4 | Technical requirements for doors – opening force for exterior doors |
| Exception 1 | 11B-404.2.9, Exception 1 | Exception for doors to machinery spaces |
| Exception 2 | 11B-404.2.9, Exception 2, including items a through e | Exception for banks of doors |
| 1133B.2.5.1 Door closer. | 11B-404.2.8.1 Door Closers and Gate Closers | Technical requirements for doors – door closer speed |
| 1133B.2.5.2 | <ul style="list-style-type: none"> • 11B-404.2.7 Door and Gate Hardware • 11B-309.4 Operation | Technical requirements for doors – door hardware |
| 1133B.2.6 Smooth surface. | 11B-404.2.10 Door and Gate Surfaces | Technical requirements for doors – surfaces within 10 inches of the floor |
| 1133B.3 Corridors, hallways and exterior exit balconies. | 11B-403.5.1, Clear Width | General technical requirements for width of accessible routes |
| 1133B.3.1 Corridor and hallway widths. | 11B-403.5.1, Exception 2 | Exception to the requirement for a 36" minimum wide accessible route – corridors serving an occupant load of 10 or more require a 44" minimum width |
| 1133B.3.2 Corridors and hallways over 200 feet (60 960 mm). | 11B-403.5.3 Passing Spaces | Technical requirements for corridors and hallways over 200 feet – 60" width or passing spaces |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1133B.4 Stairways. | 11B-210.1 General | Scoping for stairways |
| 1133B.4.1 Handrails. | <ul style="list-style-type: none"> • 11B-504.6 Handrails • 11B-505 Handrails | Technical requirements for handrails at stairways |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|-----------------------------------|---|--|
| 1133B.4.1.1 Required handrails. | <ul style="list-style-type: none"> • 11B-505.2 Where Required • 11B-505.3 Continuity | Technical requirements for handrails at stairways – along both sides, continuous |
| 1133B.4.2 Handrail configuration. | N/A | |
| 1133B.4.2.1 | 11B-505.4 Height | Technical requirements for handrails at stairways – height |
| 1133B.4.2.2 | <ul style="list-style-type: none"> • 11B-505.10 Handrail Extensions • 11B-505.10.2 Top Extension at Stairs • 11B-505.10.3 Bottom Extension at Stairs | Technical requirements for handrails at stairways – extensions at top and bottom |
| Exception 1 | 11B-505.3 Continuity | Technical requirements for handrails at stairways – switchback or dogleg stairs |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1133B.4.2.3 | <ul style="list-style-type: none"> • 11B-505.10 Handrail Extensions • 11B-505.10.2 Top Extension at Stairs • 11B-505.10.3 Bottom Extension at Stairs | Technical requirements for handrails at stairways – extensions at top and bottom |
| 1133B.4.2.4 | <ul style="list-style-type: none"> • 11B-505.10 Handrail Extensions | Technical requirements for handrails at stairways – handrail orientation |
| 1133B.4.2.5 | 11B-505.5 Clearance | Technical requirements for handrails at stairways - clearance |
| 1133B.4.2.6 Handgrips. | <ul style="list-style-type: none"> • 11B-505.6 Gripping Surface • 11B-505.7 Cross Section • 11B-505.8 Surfaces | Technical requirements for handrails at stairways – gripping surface |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1133B.4.3 Tactile floor identification signs in stairways. | 11B-504.8 Floor Identification | Technical requirements for stairways – tactile floor level identification signs This requirement was brought forward from the 2010 CBC, not a requirement of the 2010 ADAS |
| 1133B.4.4 Striping for the visually impaired. | 11B-504.4.1 Contrasting Stripe | Technical requirements for stairways – contrasting stripe This requirement was brought forward from the 2010 CBC, not a requirement of the 2010 ADAS |
| 1133B.4.5 Stair treads, risers and nosing. | 11B-504.2 Treads and Risers | Technical requirements for stairways - tread depth and riser height |
| 1133B.4.5.1 Treads. | <ul style="list-style-type: none"> • 11B-504.4 Tread Surface • 11B-504.7 Wet Conditions | Technical requirements for stairways – tread surface slip resistance and wet conditions |
| 1133B.4.5.2 Risers. | <ul style="list-style-type: none"> • 11B-504.3 Open risers • 11B-504.5 Nosings | Technical requirements for stairways – open risers not permitted and riser slope |
| Exception 1 | 11B-504.3, Exception 1 | Exception for open risers at exterior stairways – ½” opening |
| Exception 2 | 11B-504.3, Exception 2 | Exception for open risers at exterior stairways – grating |
| 1133B.4.5.3 Nosing. | 11B-504.5 Nosings | Technical requirements for stairways – nosings |
| Exception 1 | 11B-504.5, Exception | Exception for existing buildings |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 3 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1133B.5 Ramps. | <ul style="list-style-type: none"> • 11B-402.2 Components • 11B-405 Ramps | General technical requirements for ramps |
| 1133B.5.1 General. | <ul style="list-style-type: none"> • 11B-403.3 Slope • 11B-405.1 General | Technical requirements for ramps - slope |
| 1133B.5.2 Width | 11B-405.5 Clear Width | Technical requirements for ramps - width |
| 1133B.5.3 Slope. | <ul style="list-style-type: none"> • 11B-405.2 Slope • 11B-405.6 Rise | Technical requirements for ramps – maximum slope and rise |
| 1133B.5.3.1 | 11B-405.3 Cross Slope | Technical requirements for ramps – maximum cross slope |
| 1133B.5.4 Landings. | <ul style="list-style-type: none"> • 11B-405.7 Landings • 11B-405.7.1 Slope | Technical requirements for ramp landings – general requirement for level landings |
| 1133B.5.4.1 Location of landings. | <ul style="list-style-type: none"> • 11B-405.6 Rise • 11B-405.7 Landings | Technical requirements for ramp landings – top and bottom landings at each ramp run, rise of any ramp run not to exceed 30” maximum |
| 1133B.5.4.2 Size of top and bottom landings. | <ul style="list-style-type: none"> • 11B-405.7.2 Width • 11B-405.7.2.1 (Top landings) • 11B-405.7.3 Length • 11B-405.7.3.1 (Bottom landings) | Technical requirements for ramp landings – dimensions of top and bottom landings |
| 1133B.5.4.3 Doors at ramp landings. | 11B-405.7.5 Doorways | Technical requirements for ramp landings – doors at landings |
| 1133B.5.4.4 Encroachment of doors at ramp landings. | 11B-405.7.5 Doorways | Technical requirements for ramp landings – doors at landings |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 1133B.5.4.5 Landing width. | 11B-405.7.2 Width | Technical requirements for ramp landings – width |
| 1133B.5.4.6 Change of direction. | 11B-405.7.4 Change in Direction | Technical requirements for ramp landings – change in direction |
| 1133B.5.4.7 Other intermediate landings. | 11B-405.7.3 Length | Technical requirements for ramp landings – length of intermediate landings |
| 1133B.5.4.8 | <ul style="list-style-type: none"> • 11B-405.7.2 Width • 11B-405.7.3 Length | Technical requirements for ramp landings – dimensions of top and bottom landings |
| 1133B.5.4.9 Hazards. | <ul style="list-style-type: none"> • 11B-405.9 Edge Protection • 11B-405.9.2 Curb or Barrier | Technical requirements for ramps – edge protection |
| 1133B.5.5 Handrails for ramps. | 11B-405.8 Handrails | General technical requirements for ramp handrails |
| 1133B.5.5.1 | <ul style="list-style-type: none"> • 11B-405.8 Handrails • 11B-307.2 Protrusion Limits Exception • 11B-505.1 General • 11B-505.2 Where Required • 11B-505.3 Continuity • 11B-505.4 Height • 11B-505.5 Clearance • 11B-505.6 Gripping Surface • 11B-505.7 Cross Section • 11B-505.8 Surfaces • 11B-505.9 Fittings • 11B-505.10 Handrail Extensions • 11B-505.10.1 Top and Bottom Extension at Ramps | <p>Technical requirements for ramp handrails – continuity, height, clear between wall, gripping surface dimensions, smooth surfaces, fittings and top and bottom extensions</p> <p>Provision for handrails to project into the required clear width a distance of 3-1/2 inches from each side of a ramp at the handrail height not carried forward to allow for 2010 ADAS non-circular handrail cross section.</p> |
| Exception 1 | 11B-405.8, Exception 2 | Exception for handrails adjacent to fixed seating in assembly areas |
| Exception 2 | 11B-405.8, Exception 3 | Exception for handrails at curb ramps |
| Exception 3 | 11B-405.8, Exception 4 | Exception for handrails at door landings at ramps less than 6” in rise or 72” in length |
| 1133B.5.5.1.1 Ramp handrails. | 11B-505.10 Handrail Extensions Exception 3 | Model code amended to add handrail extension at hazard turned 90 degrees. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 1133B.5.6 Guide curbs and wheel guide rails. | <ul style="list-style-type: none"> • 11B-405.9 Edge Protection • 11B-405.9.2 Curb or Barrier | Technical requirements for ramps – edge protection |
| 1133B.5.6.1 | 11B-405.9.2 Curb or Barrier | Technical requirements for ramps – edge protection |
| 1133B.5.6.2 | 11B-405.9.2 Curb or Barrier | Technical requirements for ramps – edge protection |
| 1133B.5.7 Guards. | Chapter 10, Section 1013.2 Where required | Technical requirements for guards at ramps located more than 30 inches above the floor. |
| 1133B.5.8 Outdoor ramps. | 11B-405.10 Wet Conditions | Technical requirements for ramps – wet conditions |
| 1133B.6 Aisles. | 11B-403 Walking Surfaces | General technical requirements for aisles |
| 1133B.6.1 General. | Chapter 10, Section 1017 | General technical requirements for aisles |
| 1133B.6.2 Width. | <ul style="list-style-type: none"> • 11B-403.5.1 Clear Width • 11B-403.5.1, Exception | Technical requirements for aisle width |
| 1133B.7 Walks and sidewalks. | <ul style="list-style-type: none"> • 11B-403 Walking Surfaces • 11B-302.1 General | General technical requirements for walks and sidewalks |
| 1133B.7.1 Continuous surface. | <ul style="list-style-type: none"> • 11B-403.1 General • 11B-403.2 Floor or Ground Surface • 11B-403.5.1, Exception 3 • 11B-403.5.3 Passing Spaces • 11B-302.1 General | General technical requirements for walks and sidewalks – continuous surface, no abrupt level changes, 48” width, and passing spaces |
| Exception | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1133B.7.1.1 Slopes less than 6 percent. | 11B-403.2 Floor or Ground Surface | Technical requirements for walks and sidewalks – slip resistant surface |
| 1133B.7.1.2 Slopes 6 percent or greater. | 11B-403.2 Floor or Ground Surface | Technical requirements for walks and sidewalks – slip resistant surface |
| 1133B.7.1.3 Surface cross slopes. | 11B-403.3 Slope | Technical requirements for walks and sidewalks – slope and cross slope |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| 1133B.7.2 Gratings. | 11B-302.3 Openings | Technical requirements for walks and sidewalks – gratings or openings |
| Exception 1 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| Exception 2 | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1133B.7.3 Five-percent gradient. | 11B-401.1 Scope | Technical requirements for accessible route components |
| 1133B.7.4 Changes in level. | 11B-403.4 Changes in Level | Technical requirements for walks and sidewalks – changes in level |
| 1133B.7.5 Level areas. | 11B-403.7 Continuous Gradient | Technical requirements for walks and sidewalks – level areas on continuous gradients |
| 1133B.8 Hazards. | N/A | |
| 1133B.8.1 Warning curbs. | 11B-303.5 Warning Curbs | Technical requirements for changes in level - warning curbs at abrupt changes in level exceeding 4 inches Requirements for warning curbs brought forward from 2010 CBC, no comparable requirement in the 2010 ADAS |
| 1133B.8.2 Overhanging obstructions. | 11B-307.4 Vertical Clearance | Technical requirements for overhanging obstructions – need for guardrails or barriers where vertical clearance is less than 80" |
| 1133B.8.3 Detectable warnings at transit boarding platforms. | 11B-705.1.2.1 Platform Edges | Technical requirements for detectable warning at platform boarding edges |
| 1133B.8.4 Detectable directional texture at boarding platforms. | 11B-705.2 Detectable Directional Texture | Technical requirements for directional texture at platform boarding edges |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|---|---|
| 1133B.8.5 Detectable warnings at hazardous vehicular areas. | 11B-705.1.2.5 Hazardous Vehicular Areas | Technical requirements for detectable warning at hazardous vehicular areas |
| 1133B.8.6 Protruding objects. | <ul style="list-style-type: none"> • 11B-204 Protruding Objects • 11B-307 Protruding Objects | General technical requirements for protruding objects |
| 1133B.8.6.1 General. | <ul style="list-style-type: none"> • 11B-307.2 Protrusion Limits • 11B-307.3 Post-Mounted Objects | Technical requirements for protruding objects and post-mounted objects |
| 1133B.8.6.2 Head room. | 11B-307.4 Vertical Clearance | Technical requirements for overhanging obstructions – need for guardrails or barriers where vertical clearance is less than 80" |
| 1133B.8.6.3 Free-standing signs. | <ul style="list-style-type: none"> • 11B-307.3 Post-Mounted Objects • 11B-307.3.1 Edges and Corners | Technical requirements for post-mounted objects and requirement to round or ease the corners of signs |
| 1133B.8.7 Detectable warnings at reflecting pools. | 11B-705.1.2.6 Reflecting Pools | Technical requirements for detectable warning at reflecting pools |

Section 1134B – Accessibility for Existing Buildings

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|---|
| 1134B.1 Scope, 1 st paragraph | <ul style="list-style-type: none"> • 11B-201.1 Scope • 11B-202.1 General • 11B-202.2 Additions | <p>Applies requirements to all areas of new and altered buildings and facilities. Renovations are considered an alteration</p> <p>Applies requirements to additions to existing buildings and facilities.</p> |
| 1134B.1 Scope, 2 nd paragraph | 11B-202.3.1 Prohibited Reduction in Access | Existing 2010 CBC requirement being maintained. |
| 1134B.2 General. | <ul style="list-style-type: none"> • 11B-202.2 Additions • 11B-202.3 Alterations | Additions must comply with the requirements for new construction. In alterations each element or space altered must comply with the requirements of Division 2 and Section 11B-202 Existing Buildings. |
| 1134B.2.1 – Primary entrance . . . primary path of travel . . . and sanitary facilities, drinking fountains, signs and public telephones serving the area (of alteration). | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. | Existing 2010 CBC exceptions being maintained. |
| Exception 1. Disproportionate cost exception with threshold. | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | Existing 2010 CBC exceptions being maintained. |
| 1.1 through 1.6 - List of elements in priority order for disproportionate costs exception. | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8, Items 1 through 6. | Existing 2010 CBC exceptions being maintained. |
| Exception 2. Certain types of privately funded multi-story buildings and facilities . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 9. | Existing 2010 CBC exceptions being maintained. |
| 2.1. Office buildings and passenger vehicle service stations . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 9, Item 1. | Existing 2010 CBC exceptions being maintained. |
| 2.2. Office of physicians and surgeons. | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 9, Item 2. | Existing 2010 CBC exceptions being maintained. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|---|--|--|
| 2.3. Shopping centers. | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 9, Item 3. | Existing 2010 CBC exceptions being maintained. |
| 2.4. Other buildings and facilities . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 9, Item 4. | Existing 2010 CBC exceptions being maintained. |
| Exception 3. Alterations . . . limited to the actual work of the project. | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 3. | Existing 2010 CBC exceptions being maintained. |
| 3.1. Altering one building entrance . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 3, Item 1. | Existing 2010 CBC exceptions being maintained. |
| 3.2. Altering on existing toilet facility . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 3, Item 2. | Existing 2010 CBC exceptions being maintained. |
| 3.3. Altering existing elevators . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 3, Item 3. | Existing 2010 CBC exceptions being maintained. |
| 3.4. Altering existing steps . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 3, Item 4. | Existing 2010 CBC exceptions being maintained. |
| 3.5. Altering existing handrails . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 3, Item 5. | Existing 2010 CBC exceptions being maintained. |
| 3.6 Alterations solely for the purpose of barrier removal . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4. | Existing 2010 CBC exceptions being maintained. |
| 3.6.1. Installing Ramps | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 1. | Existing 2010 CBC exceptions being maintained. |
| 3.6.2. Making curb cuts . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 2. | Existing 2010 CBC exceptions being maintained. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|--|
| 3.6.3. Repositioning shelves | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 3. | Existing 2010 CBC exceptions being maintained. |
| 3.6.4. Rearranging . . . furniture | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 4. | Existing 2010 CBC exceptions being maintained. |
| 3.6.5. Repositioning telephones | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 5. | Existing 2010 CBC exceptions being maintained. |
| 3.6.6. Adding raised markings on elevator control buttons. | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 6. | Existing 2010 CBC exceptions being maintained. |
| 3.6.7. Installing flashing alarm lights | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 7. | Existing 2010 CBC exceptions being maintained. |
| 3.6.8. Widening doors. | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 8. | Existing 2010 CBC exceptions being maintained. |
| 3.6.9 Installing offset hinges . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 9. | Existing 2010 CBC exceptions being maintained. |
| 3.6.10 Eliminating a turnstile or . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 10. | Existing 2010 CBC exceptions being maintained. |
| 3.6.11. Installing accessible door hardware | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 11. | Existing 2010 CBC exceptions being maintained. |
| 3.6.12. Installing grab bars . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 12. | Existing 2010 CBC exceptions being maintained. |
| 3.6.13 Rearranging toilet partitions . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 13. | Existing 2010 CBC exceptions being maintained. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|---|
| 3.6.14. Insulating lavatory pipes . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 14. 11B-606.5 Exposed Pipes and Surfaces | Existing 2010 CBC exceptions being maintained. Technical requirements for protecting exposed pipes and surfaces. |
| 3.6.15 Installing a raised toilet seat. | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 15. | Existing 2010 CBC exceptions being maintained. |
| 3.6.16 Installing a full length bathroom mirror. | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 16. | Existing 2010 CBC exceptions being maintained. |
| 3.6.17 Repositioning paper towel dispensers . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 17. | Existing 2010 CBC exceptions being maintained. |
| 3.6.18 Creating designated accessible parking spaces. | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 18. | Existing 2010 CBC exceptions being maintained. |
| 3.6.19 Installing a paper cup dispenser at an existing water fountain. | N/A | Existing 2010 CBC exceptions not carried forward. |
| 3.6.20 Removing high-pile low-density carpeting. | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 4, Item 19. | Existing 2010 CBC exceptions being maintained. |
| 3.6.21 Installing vehicle hand controls. | N/A | The installation of vehicular hand control is not a building code item and has not been retained. |
| 3.7 Altering existing parking lots . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 5. | Existing 2010 CBC exceptions being maintained. |
| Exceptions: 4. Projects . . . not considered alteration projects . . . | 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 7. | Existing 2010 CBC exceptions being maintained. |

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|--|---|---|
| 1134B.2.2 Unisex toilet when technically infeasible to install separate toilet facilities for each gender. | <ul style="list-style-type: none"> • 11B-202.3 Alterations. Exception 2. Technically Infeasible. • 11B-202.4 Path of Travel Requirements in Alterations, Additions and Structural Repairs. Exception 8. | The Unreasonable Hardship exceptions for specific situations are replaced by provisions for, technical infeasibility and an unreasonable hardship for path of travel improvements. These exceptions must be developed by the applicant on a case-by-case basis for submission to the enforcing authority for its consideration and, if approved, documentation to its file. |
| 1134B.2.3 If alterations of Single elements . . . | 11B-202.3.3 Alterations of Single Elements | |

Section 1135B Historic Preservation-Special Standards for Accessibility for Buildings with Historical Significance

| 2010 CBC Chapter 11B | 2013 CBC Chapter 11B | Comments |
|----------------------|---|---|
| 1135B.1 General. | 11B-202.5 Alterations to Qualified Historic Buildings and Facilities. | Current reference to State Historic Building Code accessibility provisions is maintained in 2013 CBC. |

Chapter 11C – Standards for Card Readers at Gasoline Fuel-Dispensing Facilities

| 2010 CBC Chapter 11C | 2013 CBC Chapter 11B | Comments |
|---|---|---|
| 1101C.1 General. | | |
| Accessible | Chapter 2 - Section 202 | Definition of Accessible |
| Accessible Element | Chapter 2 - Section 202 | Definition of Accessible Element |
| Alternate Card Reader | | Not carried forward |
| Free-Standing Pedestal | | Not carried forward |
| Grade | Chapter 2 - Section 202 | Definition of Grade |
| International Symbol of Accessibility | Chapter 2 - Section 202 | Definition of International Symbol of Accessibility |
| Level Accessible Area | | Not carried forward |
| Level Area | Chapter 2 - Section 202 | Definition of Level Area |
| Recommend | Chapter 2 - Section 202 | Definition of Recommend |
| Type of Motor Fuel | | Not carried forward |
| Section 1102C Application | N/A | |
| 1. | 11B-201.1 Scope | Scoping for new construction and alterations required to be accessible. |
| 2. 2.1 2.2 | <ul style="list-style-type: none"> • 11B-201.1 Scope • 11B-203.2 Alterations | Scoping for new construction and alterations required to be accessible. Does not address alteration as removal and replacement of tanks, piping or fuel dispensers. |
| Section 1103C Number of Accessible Card Readers | 11B-228 Depositories, Vending Machines, Change Machines, Mail Boxes, and Fuel Dispensers | Scoping for number of fuel dispensers required. |
| Section 1104C Required Features | 11B-228.1 General | Scoping for number of fuel dispensers required to be accessible. |
| 1. | <ul style="list-style-type: none"> • 11B-308.3.1 Unobstructed, Exception 2. • 11B-308.3.2 Obstructed High Reach, Exception 2. | Technical requirements for reach range at fuel dispensers. |
| Exception: | | Not carried forward |

| 2010 CBC Chapter 11C | 2013 CBC Chapter 11B | Comments |
|----------------------|---|---|
| 2. | 11B-206.2.2 Within a Site | Scoping for accessible routes to connect accessible elements on the same site. |
| 3. | <ul style="list-style-type: none"> <li data-bbox="578 317 850 344">• 11B-305.6 Approach <li data-bbox="578 407 951 464">• 11B-308.3.2 Obstructed High Reach, Exception 2. | <p data-bbox="989 317 1365 373">Location of clear floor or ground space on accessible route.</p> <p data-bbox="989 407 1382 464">Technical requirements for reach range at fuel dispensers.</p> |

Section 1101A Application

| 2010 CBC Chapter 11A | 2013 CBC Chapter 11B | Comments |
|---------------------------------------|---|--|
| Section 1101A APPLICATION | Chapter 1, Scope and Administration Reference to Chapter 1, Section 1.1 General 1.1.3 Scope 1.1.3.2 State Regulated Buildings, 7. Section 1.9 Division of the State Architect 1.9.1.1 Application 1.9.1.1.3 | Reference to Chapter 1, Scope and Application |
| 1101A.1 Scope | N/A | Title only in 2010 CBC |
| 1. All newly constructed.... | 11B-233.3.1 Minimum Number: New Construction | Scoping for number of publicly housing facilities with residential dwelling units. |
| 2. New common use spaces... | <ul style="list-style-type: none"> • 11B-203.8 Residential Facilities • 11B-206.2.3, Item 4. Multi-Story Buildings and Facilities | General Scoping for common use areas in residential facilities. |
| 3. Additions to existing buildings... | 11B-233.3.3 Additions | General Scoping for additions to existing public housing facility. |
| 4. Common-use areas... | <ul style="list-style-type: none"> • 11B-203.8 Residential Facilities • 11B-206.2.3, Item 4. Multi-Story Buildings and Facilities | General Scoping for common and public use areas in residential facilities. |
| 5. Where any portion of a building... | 11B-233.3.4.1 Alterations to Vacated Buildings. Exception | General Scoping for alterations to vacated buildings. |

Section 1102A Building Accessibility

| 2010 CBC Chapter 11A | 2013 CBC Chapter 11B | Comments |
|---|--|---|
| 1102A Building Accessibility | N/A | Title only in 2010 CBC |
| 1102A.1 Where required. | <ul style="list-style-type: none"> • 11B-104.2 Calculation of Percentages • 11B-233.3.1 Exception • 11B-233.3.1.2.4 Exception | Scoping for number of units on a site that must comply. |
| 1. Apartment Buildings ... | <ul style="list-style-type: none"> • 11B-233.2 Residential dwelling units subject to HUD. • 11B-233.3 Residential dwelling units not subject to HUD. | Scoping for residential dwelling units. |
| 2. Condominiums ... | <ul style="list-style-type: none"> • 11B-233.3 Residential dwelling units not subject to HUD. • 11B-233.3 Residential dwelling units not subject to HUD. | Scoping for residential dwelling units. |
| 3. Lodging houses ... | 11B-224 Transient lodging guest rooms | Scoping for transient lodging. |
| 4. Congregate Residences ... | <ul style="list-style-type: none"> • 11B-224 Transient lodging guest rooms. • 11B-233.2 Residential dwelling units subject to HUD. • 11B-233.3 Residential dwelling units not subject to HUD. | Scoping for transient lodging and residential dwelling units. |
| 5. Dwelling with three or more efficiency units ... | <ul style="list-style-type: none"> • 11B-233.2 Residential dwelling units subject to HUD. • 11B-233.3 Residential dwelling units not subject to HUD. | Scoping for residential dwelling units. |
| 6. Shelters for homeless persons ... | 11B-224.1.5 Social service center establishments. | Scoping for social service center establishments. |
| 7. Dormitories ... | 11B-224 Transient lodging guest rooms. | Scoping for transient lodging. |
| 8. Timeshare dwellings ... | 11B-224 Transient lodging guest rooms. | Scoping for transient lodging. |
| 9. Other Group R occupancies ... | <ul style="list-style-type: none"> • 11B-224 Transient lodging guest rooms. • 11B-233 Residential facilities. | Scoping for transient lodging and residential dwelling units. |

| 2010 CBC Chapter 11A | 2013 CBC Chapter 11B | Comments |
|--|--|---|
| 10. Publicly funded housing, ... | Chapter 2 - Definitions | Definition of public housing. |
| 1102A.2 Existing buildings. | 11B-233.3.4 Alterations | Scoping for alterations to public housing facilities. |
| 1102A.3 Multistory dwellings. | N/A | Title only in 2010 CBC |
| 1102A.3.1 Multistory apartment or condominium dwellings in buildings with no elevator. | 11B-233.3.1.2.4 Multi-story residential dwelling units. Exception | General Scoping for number of multistory residential dwelling units required in non-elevator buildings. |
| 1. The primary entry... | <ul style="list-style-type: none"> • 11B-206.4.6 Residential dwelling unit primary entry. • 11B-233.3.1.2.5 Public housing facility site impracticability. | General Scoping for residential dwelling unit primary entrance and site impracticability. |
| 2. At least one powder room.... | 11B-233.3.1.2.4 Multi-story residential dwelling units. Exception 2 | General Scoping for powder room on first floor of multistory residential dwelling unit. |
| 3. At rooms or spaces on primary entry level ... | 11B-233.3.1.2.4 Multi-story residential dwelling units. Exception 3 | General Scoping for accessible route on primary entry level of multistory residential dwelling unit. |
| 4. Common use areas ... | <ul style="list-style-type: none"> • 11B-203.8 Residential facilities. • 11B-206.2.3, Multi-story buildings and facilities. Item 4. | General Scoping for common and public use areas in residential facilities. |
| The minimum number of | 11B-233.3.1.2.4 Multi-story residential dwelling units. Exception | General Scoping for number of multistory residential dwelling units required in non-elevator buildings. |
| 1102A.3.1 Multistory apartment or condominium dwellings in buildings with one or more elevators. | 11B-233.3.1.2.4 Multi-story residential dwelling units. | General Scoping for number of multistory residential dwelling units required in buildings with one or more elevators. |
| | 11B-233.3.1.2.4 Multi-story residential dwelling units. Exception: Item 2 | General Scoping for powder room on first floor of multistory residential dwelling unit. |
| | 11B-233.3.1.2.4 Multi-story residential dwelling units. Exception: Item 3 | General Scoping for rooms or spaces on accessible route with Chapter 11A, Division IV – Dwelling Unit Features |

Section 1104A Covered Multifamily Dwellings

| 2010 CBC Chapter 11A | 2013 CBC Chapter 11B | Comments |
|------------------------------------|---|---|
| 1104A.1 General. | <ul style="list-style-type: none">• 11B-233.3.1.2.2 Non-elevator buildings.• 11B-233.3.1.2.5 Public housing site impracticability. | General Scoping for residential dwelling units required to be adaptable and number exempted by site impracticability. |
| 1104A.2 Ground floors above grade. | 11B-233.3.1.2.3 Ground floors above grade. | General Scoping for residential dwelling units with ground floor above grade. |

Section 1106A Site and Building Characteristics

| 2010 CBC Chapter 11A | 2013 CBC Chapter 11B | Comments |
|---|-------------------------------------|---|
| 1106A.1 General Covered multifamily dwellings with elevators..... | | |
| 2. Elevator building. | 11B-233.3.1.2.1 Elevator buildings. | General Scoping for residential dwelling units required to be adaptable in buildings with elevator. |

Section 1109A Parking Facilities

| 2010 CBC Chapter 11A | 2013 CBC Chapter 11B | Comments |
|----------------------------|-----------------------|--|
| 1109A.2.1 Private Garages. | 11B-208.3.3 | General Scoping for private garages accessory to residential dwelling units. |
| Exception: | 11B-208.3.3.2 | |
| 1. A door leading... | 11B-208.3.3.2, Item 1 | General Scoping for access to residential dwelling unit from private garage. |
| 2. An accessible route... | 11B-208.3.3.2, Item 2 | General Scoping for access to residential dwelling unit from private garage. |
| 3. An accessible route... | 11B-208.3.3.2, Item 3 | General Scoping for access to residential dwelling unit from private garage. |

Section 1114A Exterior Ramps and Landings on Accessible Routes

| 2010 CBC Chapter 11A | 2013 CBC Chapter 11B | Comments |
|--|---------------------------------------|--|
| 1114A.1 Width. The width of ramps ... | | |
| 2. Ramps serving accessible entrances | 11B-405.5 Clear Width Exception 3. | Technical requirements for ramps serving accessible entrance of residential dwelling unit. |

Division IV Dwelling Unit Features

| 2010 CBC Chapter 11A | 2013 CBC Chapter 11B | Comments |
|---|---|---|
| Section 1130A Accessible route within covered multi-family dwelling units | 11B-233.3.1.2 Residential dwelling units with adaptable features. | Scoping for adaptable residential dwelling units in public housing facilities. Reference to Chapter 11A, Division IV for technical requirements of features in adaptable residential dwelling units. |
| Section 1131A - Changes in Level | 11B-233.3.1.2 Residential dwelling units with adaptable features. | Scoping for adaptable residential dwelling units in public housing facilities. Reference to Chapter 11A, Division IV for technical requirements of features in adaptable residential dwelling units. |
| Section 1132A - Doors | 11B-233.3.1.2 Residential dwelling units with adaptable features. | Scoping for adaptable residential dwelling units in public housing facilities. Reference to Chapter 11A, Division IV for technical requirements of features in adaptable residential dwelling units. |
| Section 1133A – Kitchens | 11B-233.3.1.2 Residential dwelling units with adaptable features. | Scoping for adaptable residential dwelling units in public housing facilities. Reference to Chapter 11A, Division IV for technical requirements of features in adaptable residential dwelling units. |
| Section 1134A – Bathing and Toilet Facilities | 11B-233.3.1.2 Residential dwelling units with adaptable features. | Scoping for adaptable residential dwelling units in public housing facilities. Reference to Chapter 11A, Division IV for technical requirements of features in adaptable residential dwelling units. |
| Section 1135A – Laundry Rooms | 11B-233.3.1.2 Residential dwelling units with adaptable features. | Scoping for adaptable residential dwelling units in public housing facilities. Reference to Chapter 11A, Division IV for technical requirements of features in adaptable residential dwelling units. |

| 2010 CBC Chapter 11A | 2013 CBC Chapter 11B | Comments |
|---|---|--|
| Section 1136A – Electrical Receptacle, Switch and Control Heights | 11B-233.3.1.2 Residential dwelling units with adaptable features. | <p>Scoping for adaptable residential dwelling units in public housing facilities.</p> <p>Reference to Chapter 11A, Division IV for technical requirements of features in adaptable residential dwelling units.</p> |

Division VI Site Impracticality Tests

| 2010 CBC Chapter 11A | 2013 CBC Chapter 11B | Comments |
|---|--|--|
| Section 1150A.1 Site Impracticality Tests | 11B-233.3.1.2.5 Public Housing Facility Site Impracticality. | Scoping for number of residential dwelling units required after determination of site impracticality. |
| Section 1150A.2, Additional requirements <ol style="list-style-type: none"> 1. Grab bar reinforcement 2. Doors 3. Communication features 4. Electrical receptacles and switches 5. Toilet and bathing facilities 6. Kitchen sink removable cabinets | 11B-233.3.1.2.5 Public Housing Facility Site Impracticality. | Scoping for features in residential dwelling units in remaining ground floor residential dwelling units. |